

REPORT ID: **15039.00.T209.RP3**

Cedar Point Wind Power Project – Turbine WTG10 (CP209) IEC 61400-11 Edition 3.0 Measurement Report


Prepared for:

Cedar Point II Limited Partnership
P.O. Box 5271
Forest, ON, N0N 1J0

Prepared by:

A. Munro

Allan Munro, B.A.Sc.



Payam Ashtiani, B.A.Sc., P.Eng.

09 March 2018 – Revision #3



Revision History

Revision Number	Description	Date
1	Issued Edition 2.1 test report	September 1, 2016
2	Issued Edition 3.0 test report	November 07, 2017
3	Minor changes to report tables and appendices to correct error; Update to Edition 3.0 test report Section 3.2.1 and Appendix G Information for Regulator	March 09, 2018

This report in its entirety, including appendices contains 126 pages.

Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

Table of Contents

Revision History	2
Statement Qualifications and Limitations	2
List of Appendices	6
1 Introduction	8
2 Wind Turbine Information	8
2.1 Wind turbine equipment specific information.....	8
2.2 Wind Turbine Location.....	9
3 Measurement Details	10
3.1 Measurement Equipment.....	10
3.1.1 Acoustic Measurement Equipment.....	10
3.1.2 Meteorological Equipment.....	10
3.2 Measurement Setup.....	10
3.2.1 Microphone Placement.....	10
3.2.2 Double Windscreen Setup.....	11
3.3 Measurement Schedule.....	11
3.4 Meteorological Conditions.....	11
3.5 Turbine operational information.....	12
4 Measurement Results	12
4.1 Deviations from IEC-61400-11 Edition 3.0.....	12
4.2 Special Notes & Considerations.....	12
4.3 Analysis Details.....	12
4.3.1 Double Windscreen Adjustment.....	12
4.3.2 Wind Speed Correction.....	12
4.4 Type B uncertainties.....	13
4.5 Sound Pressure Level Measurements.....	13
4.6 Sound Power Level of Turbine.....	14
4.7 Tonality Analysis.....	14
5 Closure	15
6 References	15

List of Figures

Figure A.01 – Site plan.....	Appendix A
Figure A.02 – Site photos	Appendix A
Figure B.01 – Power Curve.....	Appendix B
Figure B.02 – Rotor RPM vs. Wind Speed.....	Appendix B
Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background).....	Appendix C
Figure C.02 – Plot of measured total noise vs electrical power output.....	Appendix C
Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer.....	Appendix C
Figure C.04 - Plot of rotor RPM vs. electrical power output.....	Appendix C
Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 7 m/s.....	Appendix C
Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s.....	Appendix C
Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s.....	Appendix C
Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s.....	Appendix C
Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s.....	Appendix C
Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s.....	Appendix C
Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s.....	Appendix C
Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s.....	Appendix C
Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s.....	Appendix C
Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s.....	Appendix C
Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s.....	Appendix D
Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 7.5 m/s...Appendix D	Appendix D
Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s.....Appendix D	Appendix D
Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s...Appendix D	Appendix D
Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s.....Appendix D	Appendix D
Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s...Appendix D	Appendix D
Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s...Appendix D	Appendix D
Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s...Appendix D	Appendix D
Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s...Appendix D	Appendix D
Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s...Appendix D	Appendix D

List of Tables

Table 1 - Wind Turbine Details	8
Table 2 - Operating Details.....	8
Table 3 - Rotor Details.....	9
Table 4 - Gearbox Details.....	9
Table 5 - Generator Details	9
Table 6 - Acoustic Measurement Equipment.....	10
Table 7 – Meteorological Measurement Equipment.....	10
Table 8 - Measurement Schedule Summary	11
Table 9 - Summary of Type B uncertainties	13
Table 10 - Summary of Sound Pressure Level Measurements.....	13
Table 11 - LWA _{10m, K} at each integer wind speed	14
Table 12 - Tonality Assessment Summary.....	15
Table C.01 – Detailed apparent sound power level data at hub height.....	Appendix C
Table C.02 – Detailed apparent sound power level data at 10m height.....	Appendix C
Table C.03 – Type B measurement uncertainty summary.....	Appendix C
Table C.04 – Detailed measurement uncertainty at hub height.....	Appendix C
Table D.01 – Tonal Assessment Table – 7 m/s.....	Appendix D
Table D.02 – Tonal Assessment Table – 7.5 m/s.....	Appendix D
Table D.03 – Tonal Assessment Table – 8 m/s.....	Appendix D
Table D.04 – Tonal Assessment Table – 8.5 m/s.....	Appendix D
Table D.05 – Tonal Assessment Table – 9 m/s.....	Appendix D
Table D.06 – Tonal Assessment Table – 9.5 m/s.....	Appendix D
Table D.07 – Tonal Assessment Table – 10 m/s.....	Appendix D
Table D.08 – Tonal Assessment Table – 10.5 m/s.....	Appendix D
Table D.09 – Tonal Assessment Table – 11 m/s.....	Appendix D
Table D.10 – Tonal Assessment Table – 11.5 m/s.....	Appendix D
Table E.01 – Measurement data –Turbine ON.....	Appendix E
Table E.02 – Measurement data – Background.....	Appendix E

List of Appendices

Appendix A – Site Details

- Figure A.01 – Site plan
- Figure A.02 – Site photos

Appendix B – Turbine Information

- Figure B.01 – Power curve
- Figure B.02 – Rotor RPM vs. wind speed

Appendix C – Apparent Sound Power Level

- Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
- Figure C.02 – Plot of measured total noise vs electrical power output
- Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer
- Figure C.04 - Plot of rotor RPM vs. electrical power output
- Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 7 m/s
- Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s
- Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 8 m/s
- Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
- Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
- Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
- Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s
- Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s
- Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
- Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
- Table C.01 – Detailed apparent sound power level data at hub height
- Table C.02 – Detailed apparent sound power level data at 10m height
- Table C.03 – Type B measurement uncertainty summary
- Table C.04 – Detailed measurement uncertainty at hub height

Appendix D – Tonality Assessment

- Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s
- Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 7.5 m/s
- Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 8 m/s
- Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s
- Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s
- Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s
- Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s
- Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s
- Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s
- Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s
- Table D.01 – Tonal Assessment Table – 7 m/s
- Table D.02 – Tonal Assessment Table – 7.5 m/s
- Table D.03 – Tonal Assessment Table – 8 m/s
- Table D.04 – Tonal Assessment Table – 8.5 m/s
- Table D.05 – Tonal Assessment Table – 9 m/s
- Table D.06 – Tonal Assessment Table – 9.5 m/s
- Table D.07 – Tonal Assessment Table – 10 m/s

Table D.08 – Tonal Assessment Table – 10.5 m/s
Table D.09 – Tonal Assessment Table – 11 m/s
Table D.10 – Tonal Assessment Table – 11.5 m/s

Appendix E – Measurement Data

Table E.01 – Measurement data – Turbine ON
Table E.02 – Measurement data – Background

Appendix F – Note on anemometer position with IEC 61400-11 editions 2.1 and 3.0

Appendix G – Information for Regulator

1 Introduction

Aercoustics Engineering Limited (Aercoustics) was retained by Cedar Point II Limited Partnership to conduct an acoustic measurement of turbine WTG10 (CP209) at the Cedar Point Wind Power Project (“CPWPP”). The purpose of the measurement was to provide verification of the maximum noise emission of the turbine. The measurement was carried out in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to Turbine WTG10 (CP209).

2 Wind Turbine Information

2.1 Wind turbine equipment specific information

Wind turbine specific equipment information for turbine WTG10 (CP209) was provided by the manufacturer and is summarized in Tables 1 – 5.

Table 1 - Wind Turbine Details

Wind Turbine Details	
Manufacturer	Siemens
Model Number	SWT2.3-113
Turbine ID	2308888

Table 2 - Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal
Upwind or downwind rotor	Upwind rotor
Hub height	99.5 m
Horizontal distance from rotor centre to tower axis	5.5 m
Diameter of rotor	113 m
Tower type (lattice or tube)	Tubular
Passive stall, active stall, or pitch controlled turbine	Pitch controlled turbine
Constant or variable speed	Variable speed
Power curve	See Figure B.01
Rotational speed at each integer standardised wind speed	See Figure B.02
Rated power output	2030 kW
Control software version	128.2.0.1

Table 3 - Rotor Details

Rotor Details	
Rotor control devices	Pitch control
Presence of vortex generators, stall strips, serrated trailing edges	Vortex generators and dino tails
Blade type	B55
Serial number	Blade A: 550325801 Blade B: 550325101 Blade C: 550325601
Number of blades	3

Table 4 - Gearbox Details

Gearbox Details	
Manufacturer	N/A Direct drive
Model number	N/A Direct drive
Serial number	N/A Direct drive

Table 5 - Generator Details

Generator Details	
Manufacturer	Siemens
Model number	DD22_01
Serial number	5100049451

2.2 Wind Turbine Location

Turbine WTG10 (CP209) is in the Municipality of Lambton near the town of Forest, Ontario. Specific UTM coordinates for WTG10 (CP209) are 419153mE, 47777369mN, Zone 17T. The area surrounding WTG10 (CP209) is primarily flat farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

3 Measurement Details

3.1 Measurement Equipment

3.1.1 Acoustic Measurement Equipment

A summary of acoustic equipment utilized by Aercoustics for the measurement of turbine WTG10 (CP209) is summarized in Table 6.

Table 6 - Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile	22143211
Microphone	B&K 4189	2625197
Pre-amplifier	B&K 2671	2614901
Acoustic calibrator	B&K 4231	2513182

Calibration of the measurement setup was carried out before and after Aercoustics set of measurements.

3.1.2 Meteorological Equipment

Wind speed for Turbine ON was derived from the power curve (as per procedures outlined in IEC 61400-11). Wind direction for turbine ON measurements was utilized from the yaw position from turbine WTG10 (CP209). Data for background measurements was obtained from a 10m high anemometer, which was placed as per guidelines outlined in IEC-61400-11 Ed 2.1.

The meteorological equipment is summarized in Table 7

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	K2420011
Serial to Analog Converter	NOKEVAL 7470	A165152

3.2 Measurement Setup

3.2.1 Microphone Placement

The measurement microphone was setup 155m from the base of the turbine in ‘Position 1’, (i.e. downwind of the turbine, as per IEC 61400-11) at an elevation of 0m relative to the base of WTG10 (CP209). The slant distance (R_1) from microphone location to rotor centre includes the distance from rotor center (hub) to tower axis ($R_1 = 188.8$ m). The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period only, data points for which the microphone was within 15 degrees of downwind from the turbine were used. The microphone position relative to

downwind of the turbine was monitoring via the yaw angle output provided from the turbine system (discussed further in Section 3.5). During placement of the microphone the turbine was parked and the reference yaw angle for that measurement logged.

At the time of the acoustic test of WTG10 (CP209), the surrounding lands were covered with remnants of harvested corn stalks. The location of the microphone board was cleared and leveled out prior to board placement. The influence from reflecting surfaces was also considered to be negligible as there were no nearby reflecting surfaces (houses, barns etc.) in the vicinity of the microphone.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

3.2.2 Double Windscreen Setup

A double windscreen setup was not utilized.

3.3 Measurement Schedule

Table 8 provides a summary of the test date and times. Data was logged in 10 second intervals for post-processing (as per the measurement standard).

Table 8 - Measurement Schedule Summary

Date	Test Type	Start Time	Finish time
December 1, 2016	Turbine ON	12:21	12:42
	Background	12:45	13:45
	Turbine ON	13:51	14:54
	Turbine ON	15:05	15:11
	Background	15:12	15:40
	Turbine ON	15:49	16:35

3.4 Meteorological Conditions

Detailed meteorological data relevant to the measurement is provided in Appendix E.

As previously mentioned, wind speed for Turbine ON was derived from WTG10 (CP209)'s power curve (as per the standard), while wind direction was provided by WTG10 (CP209)'s yaw position. Background data was obtained from an anemometer located 10m above ground level near WTG10 (CP209).

Temperature and pressure readings during the measurement period were provided by the 10m anemometer, located near turbine WTG10 (CP209) for the duration of Aercoustics measurements.

3.5 Turbine operational information

Output data from the turbine (Power, yaw, RPM, pitch angle, and nacelle wind speed) were obtained as analog output signals that were simultaneously acquired with the acoustic and anemometer measurement data using Aercoustics data acquisition system.

4 Measurement Results

4.1 Deviations from IEC-61400-11 Edition 3.0

Originally, the test contract required measurements in accordance to edition 2.1 of the standard (61400-11) which requires the anemometer to be placed upwind of the turbine. This test report is a reprocessing of the originally acquired data and as such during the test, the anemometer position was erected in an upwind (Ed 2.1), rather than crosswind (Ed 3.0) position relative to the test turbine.

The acoustic signal to noise ratio for the noise levels is $>7.6\text{dB}$. This deviation is therefore considered to be negligible to the assessment of the maximum sound power of this turbine for this test. This method is in accordance with recommendations made by the convener of the IEC 61400-11 working group and is detailed in Note N6.023.17 and provided in Appendix F.

4.2 Special Notes & Considerations

No special notes and considerations.

4.3 Analysis Details

The following section outlines analysis of the measurement data acquired for WTG10 (CP209). The data presented is exclusive of transient events such as vehicle traffic, wildlife, air traffic etc. The site has been assessed to have a roughness length of 0.05m, representative of farmland with some vegetation.

4.3.1 Double Windscreen Adjustment

As previously mentioned, no double wind screen was used, as such the measurement data did not require adjustment.

4.3.2 Wind Speed Correction

The wind speed for each measurement data point for Turbine ON was derived through the power curve (as per Section 8.2.1.1 of IEC-61400-11). For data points during Turbine ON that were outside the allowed range of the power curve, the wind speed was derived from the nacelle anemometer wind speed (as specified in Section 8.2.1.2 of IEC-61400-11).

Background wind speed was derived utilizing data acquired with the 10m anemometer and normalizing the wind speed (as per Section 8.2.2 of IEC-61400-11).

4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of information provided in Annex C of IEC-61400-11, and instrument uncertainties obtained from the calibration certificate. A summary of Type B uncertainties is provided in Table 9, while detailed information (including data in 1/3 octave) is provided in Appendix C.

Table 9 - Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

4.5 Sound Pressure Level Measurements

Sound pressure level measurements are summarized in Table 10. Detailed 1/3 Octave band spectrum data, respective uncertainties, and analysis plots are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E and includes meteorological and turbine operational data.

Table 10 - Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted L_{eq} , (dBA)
	L_{eq} , (dBA)	# of data pts	L_{eq} , (dBA)	# of data pts	
7	50.2	21	39.5	13	49.8
7.5	51.7	21	39.9	20	51.4
8	51.9	21	42.0	16	51.5
8.5	52.1	23	40.8	25	51.7
9	52.0	17	42.2	30	51.6
9.5	51.8	61	42.4	37	51.3
10	51.9	85	43.7	32	51.2
10.5	52.1	83	44.2	37	51.3
11	52.1	105	44.4	35	51.3
11.5	52.2	61	44.2	30	51.5

4.6 Sound Power Level of Turbine

The calculated sound power level of the turbine WTG10 (CP209) (as per IEC 61400-11) is summarized in Table 11 (hub height) and Table 12 (10m height). Detailed 1/3 Octave band spectrum data and respective uncertainties are provided in Appendix C.

Table 11 - $L_{WA, K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
7	100.3	0.8
7.5	101.9	0.8
8	102.0	0.8
8.5	102.2	0.8
9	102.1	0.8
9.5	101.8	0.8
10	101.7	0.9
10.5	101.8	0.9
11	101.8	0.9
11.5	102.0	0.9

Table 12 - $L_{WA 10m, K}$ at each integer wind speed

Wind Speed (m/s)	Apparent L_{WA} , (dBA)	Uncertainty (dB)
5	100.9	0.8
6	102.1	0.8
7	101.7	0.9
8	101.9	0.8
9	102.0	1.1

4.7 Tonality Analysis

The tonality analysis for Turbine WTG10 (CP209) is summarized in Table 13, while plots of narrow band spectra at each wind speed are provided in Appendix D. The ΔL_{tn} and ΔL_a values reported represent the energy average of all data points with an identified tone that falls within the same frequency origin (as specified in Section 9.5.8 in IEC-61400-11).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 13 - Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, ΔL_{tn} (dB)	Tonal audibility, ΔL_a (dB)	FFT's with tones	Total # of FFT's	Presence (%)
7	59	-3.4	-1.4	21	21	100%
8	60	-4.0	-2.0	16	21	76%
8.5	61	-3.5	-1.5	17	23	74%
9	61	-2.6	-0.6	8	17	47%
9.5	59	-2.7	-0.7	25	61	41%
9.5	127	-4.5	-2.5	25	61	41%
10	61	-1.5	0.5	44	85	52%
10.5	61	-1.6	0.4	43	83	52%
11	60	-1.8	0.2	49	105	47%
11.5	59	-1.7	0.3	25	61	41%

5 Closure

Measurements and analysis as per International IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques” were carried on Turbine WTG10 (CP209) of the Cedar Point Wind Power Project on December 1st, 2016.

Should you have any questions or comments please do not hesitate to contact the authors of this report.

6 References

1. International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Appendix A Site Details



15039.00.T209.RP3

Project Name

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Site Plan

Figure A.01





15039.00.T209.RP3

Project Name

Scale: NTS
Drawn by: AM
Reviewed by: PA
Date: Mar 7, 2018
Revision: 1

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title


Site Photos




Figure A.02

Appendix B Turbine Information

CPWPP - SWT 2.3-113 Power Curve



Power Curve	
Hub Wind Speed (m/s)	Power [kW]
0	0
1	0
2	0
3	66
4	171
5	350
6	620
7	994
8	1454
9	1862
10	2005
11	2029
12	2030
13	2030
14	2030
15	2030
16	2030
17	2030
18	2030
19	2030
20	2030
21	2030
22	2030
23	2030
24	2030
25	2030



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0


Figure Title


Rotor RPM vs. wind speed

Figure B.02

Appendix C

Apparent Sound Power Level





15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1


Project Name

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of measured total noise vs electrical power output

Figure C.02



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of rotor RPM vs. electrical power output

Figure C.04

7.0 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 7 m/s

Figure C.05

7.5 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 7.5 m/s

Figure C.06

8.0 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8 m/s

Figure C.07

8.5 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s

Figure C.08

9.0 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9 m/s

Figure C.09

9.5 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s

Figure C.10

10.0 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 10 m/s

Figure C.11

10.5 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s

Figure C.12

11.0 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 11 m/s

Figure C.13

11.5 m/s - Hub Height



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s

Figure C.14

Table C.01 Detailed apparent sound power level data at hub height

Project: Cedar Point Wind Power Project - Turbine CP209 - IEC 61400-11 Measurement

Report ID: 15039.00.T209.RP3

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																			Overall									
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250		1600	2000	2500	3150	4000	5000	6300	8000	10000
11.0	Turbine ON (dBA)	13.9	15.6	17.9	20.6	24.1	31.9	29.4	31.5	36.5	34.6	34.3	35.9	36.9	36.5	38.6	39.9	40.7	41.3	41.8	41.4	42.1	43.2	39.4	37.9	36.3	35.1	33.1	30.2	52.1
	Background (dBA)	6.7	9.6	12.9	14.9	17.7	22.6	24.1	26.5	28.7	28.8	28.9	30.2	30.8	29.8	31.0	31.1	31.7	31.9	31.6	32.1	32.6	33.1	33.5	33.0	32.3	31.9	29.7	26.2	44.4
	Turbine ON - background adj (dBA)	13.0	14.3	16.2	19.3	22.9	31.3	27.8	29.8	35.7	33.3	32.8	34.5	35.7	35.5	37.8	39.2	40.1	40.8	41.4	40.8	41.5	42.8	38.1	36.2	34.1	32.3	30.4	28.0	51.3
	Signal to noise (dB)	7.2	5.9	5.0	5.7	6.4	9.3	5.2	5.0	7.8	5.8	5.4	5.7	6.1	6.7	7.6	8.7	9.0	9.5	10.2	9.2	9.5	10.1	5.9	4.9	4.0	3.2	3.4	4.0	7.6
	Uncertainty (dB)	1.3	1.4	1.3	1.1	1.1	0.9	1.2	1.2	1.0	1.1	1.0	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	1.1	1.3	1.5	1.9	1.8	2.6	0.9
	PWL (dBA)	63.5	64.8	66.7	69.8	73.5	81.8	78.3	80.4	86.3	83.8	83.3	85.0	86.2	86.0	88.3	89.7	90.6	91.3	91.9	91.4	92.1	93.3	88.7	86.7	84.6	82.8	80.9	78.5	101.8
11.5	Turbine ON (dBA)	13.4	15.2	17.5	20.8	24.2	32.0	29.7	31.8	36.8	34.9	34.5	36.1	37.1	36.8	38.7	40.0	40.9	41.5	42.1	41.7	42.1	43.1	39.5	37.9	36.3	35.1	33.0	30.2	52.2
	Background (dBA)	6.0	8.8	12.1	14.2	17.8	22.6	23.9	26.7	28.7	28.7	28.9	30.1	30.6	29.8	31.1	31.0	31.7	31.8	31.4	31.7	32.0	32.7	33.1	32.6	32.0	31.4	29.0	25.7	44.2
	Turbine ON - background adj (dBA)	12.5	14.1	16.0	19.7	23.1	31.4	28.3	30.3	36.1	33.6	33.1	34.8	35.9	35.8	37.9	39.4	40.3	41.0	41.7	41.2	41.7	42.7	38.4	36.4	34.3	32.7	30.8	28.3	51.5
	Signal to noise (dB)	7.4	6.4	5.4	6.6	6.5	9.4	5.8	5.2	8.1	6.1	5.6	5.9	6.4	7.0	7.7	8.9	9.2	9.7	10.6	9.9	10.1	10.4	6.4	5.3	4.3	3.7	4.0	4.5	8.0
	Uncertainty (dB)	1.3	1.4	1.2	1.0	1.0	0.9	1.1	1.2	0.9	1.1	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.9	1.0	1.2	1.4	1.7	1.6	2.3	0.9
	PWL (dBA)	63.0	64.6	66.5	70.2	73.6	81.9	78.9	80.8	86.6	84.2	83.6	85.3	86.5	86.3	88.4	89.9	90.8	91.5	92.2	91.7	92.2	93.2	88.9	86.9	84.8	83.2	81.3	78.8	102.0

Table C.02 Detailed apparent sound power level data at 10m height

Project: Cedar Point Wind Power Project - Turbine CP209 - IEC 61400-11 Measurement

Report ID: 15039.00.T209.RP3

1/3 Octave values marked with brackets [] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk * denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																		Overall										
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000		1250	1600	2000	2500	3150	4000	5000	6300	8000	10000
5.0	Turbine ON (dBA)	6.8	10.5	14.8	18.2	22.3	30.5	27.5	30.8	34.0	34.6	35.0	37.1	37.7	37.1	38.9	39.3	39.3	39.3	39.3	39.0	41.8	42.7	35.9	33.0	30.1	27.1	26.2	25.1	50.8
	Background (dBA)	0.4	4.1	9.3	10.6	14.2	20.2	21.2	23.2	25.4	23.8	24.4	25.8	26.6	25.4	28.1	27.5	28.4	28.2	27.4	27.5	27.7	28.2	28.3	27.8	27.4	26.7	24.5	21.3	40.1
	Turbine ON - background adj (dBA)	5.7	9.4	13.4	17.4	21.6	30.1	26.3	30.0	33.4	34.2	34.6	36.8	37.4	36.8	38.5	39.0	38.9	38.9	39.0	38.7	41.6	42.5	35.1	31.4	[27.1]	[24.1]	[23.2]	22.7	50.4
	Signal to noise (dB)	6.4	6.4	5.6	7.7	8.1	10.3	6.2	7.6	8.6	10.8	10.6	11.3	11.1	11.7	10.7	11.8	10.9	11.1	11.9	11.5	14.1	14.5	7.6	5.2	2.7	0.4	1.7	3.8	10.7
	Uncertainty (dB)	1.3	1.3	1.1	0.9	0.9	0.9	1.0	1.0	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	1.0	1.2	1.8	1.9	1.9	2.6	0.8
6.0	PWL (dBA)	56.2	59.9	63.9	67.9	72.1	80.6	76.8	80.5	83.9	84.8	85.1	87.3	87.9	87.4	89.0	89.6	89.5	89.4	89.5	89.2	92.1	93.0	85.6	81.9	[77.6]	[74.6]	[73.7]	73.2	100.9
	Turbine ON (dBA)	12.0	13.8	16.8	20.2	23.8	31.5	29.4	32.1	35.9	36.0	36.6	38.2	38.8	38.2	39.7	40.2	40.3	40.3	40.4	39.9	42.4	44.1	38.4	35.8	33.7	31.6	29.9	27.6	52.0
	Background (dBA)	3.1	6.0	10.0	11.3	14.6	20.6	20.4	23.3	25.6	24.2	24.4	25.8	26.9	26.2	28.8	28.9	29.5	29.6	29.2	29.1	29.9	30.4	30.7	30.5	30.1	29.4	27.2	23.8	41.7
	Turbine ON - background adj (dBA)	11.4	13.0	15.8	19.6	23.2	31.1	28.8	31.5	35.5	35.7	36.3	38.0	38.5	37.9	39.3	39.9	39.9	39.9	40.1	39.6	42.1	44.0	37.6	34.3	31.1	[28.6]	[26.9]	25.2	51.6
	Signal to noise (dB)	8.9	7.8	6.8	9.0	9.2	11.0	9.0	8.9	10.4	11.8	12.2	12.4	11.8	12.0	10.9	11.4	10.8	10.7	11.2	10.8	12.4	13.8	7.7	5.4	3.5	2.2	2.0	3.8	10.3
7.0	Uncertainty (dB)	1.2	1.3	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	1.0	1.2	1.6	2.1	2.0	2.6	0.8	
	PWL (dBA)	61.9	63.5	66.3	70.1	73.7	81.7	79.3	82.0	86.0	86.2	86.8	88.5	89.0	88.4	89.9	90.4	90.4	90.5	90.6	90.1	92.6	94.5	88.1	84.8	81.7	[79.1]	[77.4]	75.8	102.1
	Turbine ON (dBA)	13.3	14.5	17.3	20.4	24.0	31.7	29.4	31.8	36.5	34.7	34.5	36.1	37.1	36.7	38.7	39.8	40.5	41.0	41.2	40.9	42.0	43.3	39.0	37.4	35.8	34.6	32.6	29.8	51.9
	Background (dBA)	6.7	9.2	12.3	13.9	16.9	21.8	23.0	25.5	27.7	27.4	27.6	29.0	29.8	28.9	30.4	30.4	31.1	31.2	30.9	31.1	31.6	32.2	32.6	32.1	31.5	31.0	28.8	25.4	43.6
	Turbine ON - background adj (dBA)	12.2	13.0	15.6	19.4	23.0	31.3	28.3	30.7	35.8	33.8	33.5	35.2	36.2	36.0	38.0	39.3	40.0	40.5	40.8	40.4	41.6	43.0	37.9	35.9	33.8	32.1	30.2	27.8	51.2
8.0	Signal to noise (dB)	6.6	5.3	5.0	6.6	7.1	9.9	6.4	6.4	8.8	7.3	6.9	7.1	7.3	7.8	8.3	9.4	9.4	9.8	10.4	9.8	10.4	11.1	6.4	5.3	4.3	3.6	3.8	4.4	8.3
	Uncertainty (dB)	1.3	1.5	1.2	1.0	1.0	0.9	1.1	1.1	0.9	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	1.1	1.2	1.4	1.6	1.5	2.4	0.9
	PWL (dBA)	62.7	63.5	66.1	69.9	73.5	81.8	78.8	81.2	86.4	84.3	84.0	85.7	86.7	86.5	88.6	89.8	90.5	91.0	91.3	90.9	92.1	93.5	88.4	86.4	84.3	82.6	80.7	78.3	101.7
	Turbine ON (dBA)	13.8	15.7	17.9	20.8	24.3	31.9	29.6	31.7	36.8	34.7	34.4	36.0	37.0	36.6	38.7	39.9	40.8	41.5	42.0	41.6	42.1	43.1	39.6	38.1	36.5	35.3	33.3	30.4	52.2
	Background (dBA)	7.0	9.6	12.5	14.7	17.8	22.8	24.2	26.7	28.9	28.9	29.0	30.3	30.9	30.0	31.2	31.3	31.9	32.0	31.6	32.0	32.4	33.1	33.4	33.0	32.3	31.7	29.5	26.0	44.4
9.0	Turbine ON - background adj (dBA)	12.8	14.4	16.4	19.6	23.1	31.3	28.2	30.1	36.0	33.4	32.9	34.6	35.8	35.6	37.8	39.3	40.2	40.9	41.6	41.1	41.6	42.7	38.4	36.5	34.4	32.8	30.9	28.4	51.4
	Signal to noise (dB)	6.8	6.1	5.4	6.1	6.4	9.1	5.4	5.0	7.9	5.9	5.4	5.7	6.1	6.7	7.5	8.6	8.9	9.5	10.4	9.6	9.7	10.1	6.2	5.1	4.2	3.6	3.8	4.3	7.7
	Uncertainty (dB)	1.2	1.3	1.1	1.0	1.0	0.8	1.1	1.1	0.9	1.0	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	1.0	1.1	1.3	1.5	1.5	2.3	0.8
	PWL (dBA)	63.3	64.9	66.9	70.1	73.7	81.8	78.7	80.6	86.5	84.0	83.4	85.1	86.3	86.1	88.4	89.8	90.7	91.5	92.1	91.6	92.2	93.2	88.9	87.0	84.9	83.3	81.4	78.9	101.9
	Turbine ON (dBA)	14.1	15.3	18.3	21.5	24.7	31.7	30.6	32.1	37.5	34.9	34.6	36.5	37.1	36.7	38.8	40.0	41.0	41.8	42.5	42.2	42.2	42.7	40.0	38.5	36.7	35.7	33.6	30.6	52.4
9.0	Background (dBA)	8.1	10.3	12.8	14.9	18.2	22.8	24.7	27.3	29.4	29.7	29.8	31.0	31.6	30.5	31.7	31.8	32.4	32.4	32.1	32.8	33.2	33.9	34.1	33.7	33.0	32.6	30.4	26.9	45.1
	Turbine ON - background adj (dBA)	12.8	13.7	16.9	20.4	23.6	31.1	29.3	30.3	36.8	33.3	32.9	35.0	35.7	35.5	37.9	39.3	40.3	41.2	42.0	41.6	41.6	42.0	38.8	36.7	34.3	32.8	30.7	28.2	51.5
	Signal to noise (dB)	5.9	5.1	5.5	6.6	6.6	8.9	5.9	4.8	8.1	5.2	4.8	5.4	5.5	6.2	7.1	8.2	8.5	9.4	10.3	9.4	9.0	8.8	5.9	4.7	3.7	3.1	3.2	3.7	7.3
	Uncertainty (dB)	1.8	1.9	1.5	1.3	1.3	1.1	1.4	1.5	1.2	1.4	1.3	1.2	1.2	1.1	1.0	1.0	1.0	0.9	0.9	0.9	1.0	1.1	1.4	1.6	1.9	2.3	2.3	3.3	1.1
	PWL (dBA)	63.3	64.2	67.4	71.0	74.2	81.6	79.8	80.8	87.3	83.9	83.4	85.5	86.2	86.1	88.4	89.8	90.9	91.7	92.6	92.2	92.1	92.6	89.3	87.2	84.8	83.3	81.2	78.7	102.0

Table C.03 Type B measurement uncertainty summary

Project: Cedar Point Wind Power Project - Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB


1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	1 dB
25	0.8 dB	1 dB
31.5	0.5 dB	0.8 dB
40	0.5 dB	0.8 dB
50	0.5 dB	0.8 dB
63	0.5 dB	0.8 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.7 dB
1250	0.3 dB	0.7 dB
1600	0.3 dB	0.7 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	0.8 dB
4000	0.5 dB	0.8 dB
5000	0.5 dB	0.8 dB
6300	0.5 dB	0.8 dB
8000	0.5 dB	0.8 dB
10000	1.3 dB	1.4 dB

Table C.04 Detailed measurement uncertainty at hub height

Project: Cedar Point Wind Power Project - Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Wind Bin (m/s)	Parameter	Average Wind Speed (m/s)	# of data points	Parameter	1/3 Octave Band (Hz)																		Overall												
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000		1250	1600	2000	2500	3150	4000	5000	6300	8000	10000		
10.5	Turbine ON	10.49	83	Average (dBA)	13.5	14.7	17.2	20.2	23.7	31.8	29.2	31.4	36.3	34.5	34.1	35.8	36.9	36.6	38.7	39.9	40.7	41.3	41.6	41.2	42.1	43.8	39.2	37.5	35.9	34.7	32.7	29.8	52.1		
				Uncertainty A (dB)	0.2	0.2	0.2	0.2	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5
Background	10.49	37	Average (dBA)	8.1	10.5	13.5	14.8	17.3	22.2	23.3	25.8	28.0	27.8	28.2	29.6	30.5	29.7	30.9	31.0	31.7	31.8	31.6	31.9	32.3	33.0	33.4	32.9	32.3	31.7	29.5	26.0	44.2			
			Uncertainty A (dB)	1.0	0.7	0.6	0.5	0.4	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.3	0.4	0.4	0.4	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7		
			Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4		
			Combined Uncertainty (dB)	1.4	1.3	1.0	0.9	0.9	0.8	0.9	0.9	0.8	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.1	1.1	1.1	1.1	1.1	1.6		
11.0	Turbine ON	10.99	105	Average (dBA)	13.9	15.6	17.9	20.6	24.1	31.9	29.4	31.5	36.5	34.6	34.3	35.9	36.9	36.5	38.6	39.9	40.7	41.3	41.8	41.4	42.1	43.2	39.4	37.9	36.3	35.1	33.1	30.2	52.1		
				Uncertainty A (dB)	0.3	0.3	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.4	0.3	0.3	0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
				Combined Uncertainty (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.9	0.9	1.5	
Background	11.01	35	Average (dBA)	6.7	9.6	12.9	14.9	17.7	22.6	24.2	26.5	28.7	28.8	28.9	30.2	30.8	29.8	31.0	31.1	31.7	31.9	31.6	32.1	32.6	33.1	33.5	33.0	32.3	31.9	29.7	26.2	44.4			
			Uncertainty A (dB)	0.7	0.5	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7		
			Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4		
			Combined Uncertainty (dB)	1.3	1.1	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.9	1.0	1.0	1.1	1.1	1.1	1.6		
11.5	Turbine ON	11.48	61	Average (dBA)	13.3	15.1	17.4	20.7	24.2	32.0	29.7	31.8	36.8	34.9	34.5	36.0	37.1	36.8	38.7	40.0	40.9	41.5	42.1	41.6	42.1	43.2	39.5	37.9	36.2	35.0	33.0	30.2	52.2		
				Uncertainty A (dB)	0.3	0.3	0.2	0.2	0.2	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.3	0.4	0.5	0.4	0.3	0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4	
				Combined Uncertainty (dB)	1.1	1.1	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.9	0.9	0.9	1.5	
Background	11.53	30	Average (dBA)	6.0	8.8	12.0	14.1	17.8	22.6	23.9	26.7	28.7	28.7	28.9	30.1	30.6	29.8	31.1	31.0	31.7	31.8	31.4	31.7	31.9	32.7	33.1	32.6	31.9	31.3	29.0	25.6	44.2			
			Uncertainty A (dB)	0.8	0.5	0.4	0.3	0.3	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5		
			Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	1.4		
			Combined Uncertainty (dB)	1.3	1.1	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	1.0	1.0	1.5		

Appendix D Tonality Assessment



15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1


Project Name


Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0


Figure Title


Plot of narrow band spectra – Turbine ON vs. Background at 7 m/s


Figure D.01























15039.00.T209.RP3

Scale: NTS
 Drawn by: AM
 Reviewed by: PA
 Date: Mar 07, 2018
 Revision: 1

Project Name

Cedar Point Wind Power Project - Turbine CP209 - IEC61400-11 Edition 3.0

Figure Title

Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s

Figure D.10

Table D.01 Tonality Assessment Table - 7 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
658	58			18.0	36.2	30.4	-5.8	-2.0	-3.8
682	58			19.0	37.2	34.6	-2.6	-2.0	-0.6
656	58			17.8	36.1	32.9	-3.2	-2.0	-1.2
704	58			20.7	39.0	33.8	-5.2	-2.0	-3.2
697	58			18.3	36.5	31.4	-5.1	-2.0	-3.1
687	58			18.7	36.9	33.3	-3.6	-2.0	-1.6
659	58			18.1	36.4	32.9	-3.5	-2.0	-1.5
691	58			18.1	36.3	35.2	-1.1	-2.0	0.9
684	58			18.4	36.7	30.2	-6.5	-2.0	-4.5
648	58			17.2	35.4	33.6	-1.8	-2.0	0.2
680	58			19.4	37.6	33.0	-4.7	-2.0	-2.7
700	58			18.2	36.4	32.5	-4.0	-2.0	-2.0
698	59			18.4	36.7	32.9	-3.8	-2.0	-1.8
683	59			19.0	37.3	32.8	-4.5	-2.0	-2.5
693	59			17.0	35.3	32.4	-2.9	-2.0	-0.9
696	59			18.0	36.3	36.5	0.2	-2.0	2.2
692	62			18.9	37.1	32.4	-4.7	-2.0	-2.7
661	62			19.5	37.7	34.1	-3.7	-2.0	-1.7
681	62			19.0	37.2	32.9	-4.4	-2.0	-2.4
660	62			18.2	36.4	32.8	-3.7	-2.0	-1.7
657	62			18.3	36.5	32.6	-3.9	-2.0	-1.9
Average	59						-3.4	-2.0	-1.4

Table D.02 Tonality Assessment Table - 7.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
Report ID: 15039.00.T209.RP3

Page 1 of 1
Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

Table D.03 Tonality Assessment Table - 8 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
482	58			20.1	38.4	34.1	-4.2	-2.0	-2.2
616	58			19.8	38.0	33.4	-4.6	-2.0	-2.6
615	58			19.7	37.9	32.7	-5.2	-2.0	-3.2
713	58			19.5	37.7	32.5	-5.2	-2.0	-3.2
671	58			19.4	37.7	33.0	-4.7	-2.0	-2.7
670	58			19.7	38.0	34.3	-3.7	-2.0	-1.7
714	58			19.1	37.4	33.1	-4.2	-2.0	-2.2
613	58			20.8	39.0	32.0	-7.0	-2.0	-5.0
484	58			19.6	37.8	34.1	-3.7	-2.0	-1.7
676	58			21.3	39.5	34.3	-5.2	-2.0	-3.2
668	58			18.5	36.7	38.1	1.4	-2.0	3.4
674	65			21.6	39.9	33.1	-6.8	-2.0	-4.8
712	65			19.3	37.6	34.2	-3.4	-2.0	-1.4
618	65			21.1	39.3	33.1	-6.2	-2.0	-4.2
483	65			19.5	37.7	34.9	-2.8	-2.0	-0.8
486	65			21.5	39.7	33.3	-6.4	-2.0	-4.4
Average	60						-4.0	-2.0	-2.0

Table D.04 Tonality Assessment Table - 8.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
642	58			19.6	37.8	32.9	-4.9	-2.0	-2.9
485	58			21.1	39.3	37.6	-1.7	-2.0	0.3
641	58			19.6	37.8	33.0	-4.8	-2.0	-2.8
478	58			20.7	38.9	35.3	-3.6	-2.0	-1.6
612	58			20.9	39.1	34.1	-5.0	-2.0	-3.0
643	58			19.3	37.6	34.4	-3.2	-2.0	-1.2
477	58			20.1	38.3	35.6	-2.8	-2.0	-0.8
481	58			20.2	38.5	35.7	-2.7	-2.0	-0.7
607	58			20.9	39.1	35.6	-3.5	-2.0	-1.5
619	65			22.0	40.3	33.4	-6.9	-2.0	-4.8
614	65			20.0	38.2	35.8	-2.4	-2.0	-0.4
706	65			19.5	37.8	34.6	-3.1	-2.0	-1.1
620	65			22.2	40.5	34.2	-6.2	-2.0	-4.2
707	65			20.4	38.6	35.3	-3.3	-2.0	-1.3
622	65			21.9	40.2	34.5	-5.6	-2.0	-3.6
621	65			21.2	39.4	35.2	-4.3	-2.0	-2.3
705	66			20.2	38.5	37.8	-0.6	-2.0	1.4
Average	61						-3.5	-2.0	-1.5

Table D.05 Tonality Assessment Table - 9 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
611	58			20.3	38.5	34.3	-4.2	-2.0	-2.2
634	58			20.7	38.9	36.5	-2.5	-2.0	-0.5
590	58			20.7	39.0	35.3	-3.7	-2.0	-1.7
640	58			19.3	37.5	35.1	-2.5	-2.0	-0.5
360	58			21.2	39.5	37.7	-1.7	-2.0	0.3
623	65			21.0	39.2	36.1	-3.1	-2.0	-1.1
588	65			19.9	38.1	35.5	-2.7	-2.0	-0.7
487	66			21.2	39.4	38.1	-1.3	-2.0	0.7
Average	61						-2.6	-2.0	-0.6

Table D.06 Tonality Assessment Table - 9.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 2
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
232	58			20.6	38.8	36.1	-2.7	-2.0	-0.7
625	58			19.8	38.0	34.6	-3.4	-2.0	-1.4
334	58			21.8	40.0	35.9	-4.1	-2.0	-2.1
511	58			19.3	37.5	35.9	-1.6	-2.0	0.4
352	58			19.6	37.8	35.4	-2.4	-2.0	-0.4
547	58			18.6	36.9	35.9	-1.0	-2.0	1.0
14	58			21.3	39.5	35.1	-4.4	-2.0	-2.4
235	58			21.0	39.2	33.9	-5.3	-2.0	-3.3
307	58			20.5	38.7	37.3	-1.4	-2.0	0.6
535	58			20.6	38.8	34.4	-4.4	-2.0	-2.4
340	58			19.4	37.6	34.6	-3.0	-2.0	-1.0
156	58			20.7	38.9	34.9	-4.0	-2.0	-2.0
209	58			19.8	38.1	34.4	-3.7	-2.0	-1.7
499	58			20.7	38.9	36.6	-2.4	-2.0	-0.4
415	58			20.0	38.2	36.7	-1.5	-2.0	0.5
341	58			18.7	36.9	36.1	-0.8	-2.0	1.2
475	58			18.4	36.7	35.2	-1.4	-2.0	0.6
184	58			19.6	37.9	33.7	-4.2	-2.0	-2.2
479	58			20.4	38.6	34.1	-4.5	-2.0	-2.5
210	58			19.4	37.6	36.2	-1.5	-2.0	0.5
586	59			20.5	38.7	35.5	-3.2	-2.0	-1.2
96	61			19.9	38.1	33.9	-4.3	-2.0	-2.3
53	62			22.0	40.2	33.4	-6.9	-2.0	-4.9
626	65			19.8	38.1	35.3	-2.8	-2.0	-0.8
322	74			20.5	38.7	38.7	0.0	-2.0	2.0
Average	59						-2.7	-2.0	-0.7

Table D.06 Tonality Assessment Table - 9.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 2 of 2
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
36	123			24.3	42.5	36.6	-5.9	-2.0	-3.9
90	124			23.0	41.3	35.0	-6.3	-2.0	-4.3
96	124			22.8	41.1	32.6	-8.4	-2.0	-6.4
511	124			22.6	40.9	32.7	-8.2	-2.0	-6.2
53	125			23.5	41.8	33.6	-8.2	-2.0	-6.2
95	125			23.0	41.3	34.2	-7.1	-2.0	-5.1
184	126			22.0	40.3	33.4	-6.9	-2.0	-4.9
89	126			22.7	41.0	36.1	-5.0	-2.0	-2.9
216	126			22.2	40.5	37.9	-2.6	-2.0	-0.6
88	126			21.5	39.8	38.8	-0.9	-2.0	1.1
535	126			24.4	42.7	35.0	-7.8	-2.0	-5.8
291	126			23.2	41.5	37.5	-3.9	-2.0	-1.9
307	126			23.7	42.0	38.3	-3.7	-2.0	-1.7
221	126			22.7	41.0	33.0	-8.0	-2.0	-6.0
15	126			23.4	41.7	37.4	-4.3	-2.0	-2.3
20	126			24.1	42.4	33.9	-8.6	-2.0	-6.6
425	126			21.7	40.0	38.1	-1.8	-2.0	0.2
243	126			22.1	40.4	39.1	-1.3	-2.0	0.7
340	126			21.4	39.7	37.2	-2.5	-2.0	-0.5
547	126			21.7	40.0	37.6	-2.4	-2.0	-0.4
278	127			22.8	41.0	35.7	-5.4	-2.0	-3.3
109	127			22.8	41.0	37.2	-3.8	-2.0	-1.8
14	127			24.1	42.4	37.6	-4.9	-2.0	-2.9
210	127			22.8	41.1	36.9	-4.2	-2.0	-2.2
322	148			24.1	42.5	37.1	-5.4	-2.0	-3.4
Average	127						-4.5	-2.0	-2.5

Table D.07 Tonality Assessment Table - 10 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
602	58			19.7	37.9	36.3	-1.6	-2.0	0.4
447	58			18.9	37.1	36.0	-1.1	-2.0	0.9
468	58			16.6	34.8	37.4	2.6	-2.0	4.6
433	58			17.7	35.9	36.7	0.9	-2.0	2.9
438	58			20.1	38.3	35.4	-2.9	-2.0	-0.9
510	58			19.6	37.9	35.7	-2.2	-2.0	-0.2
528	58			19.8	38.0	37.1	-0.9	-2.0	1.1
461	58			18.7	36.9	35.5	-1.4	-2.0	0.6
245	58			20.0	38.2	35.6	-2.7	-2.0	-0.7
413	58			20.2	38.4	37.4	-1.0	-2.0	1.0
585	58			20.6	38.8	35.2	-3.6	-2.0	-1.6
598	58			19.5	37.7	37.0	-0.7	-2.0	1.3
633	58			21.4	39.7	34.9	-4.7	-2.0	-2.7
551	58			16.7	35.0	36.0	1.1	-2.0	3.1
453	58			21.3	39.5	36.0	-3.5	-2.0	-1.5
549	58			17.5	35.7	36.8	1.0	-2.0	3.0
252	58			19.5	37.7	35.2	-2.5	-2.0	-0.5
536	58			21.0	39.2	35.7	-3.5	-2.0	-1.5
542	58			21.3	39.5	34.4	-5.1	-2.0	-3.1
458	58			17.7	35.9	36.4	0.5	-2.0	2.5
506	58			19.3	37.6	35.6	-2.0	-2.0	0.0
437	58			18.3	36.6	36.9	0.3	-2.0	2.3
520	58			20.3	38.5	36.1	-2.4	-2.0	-0.4
377	58			19.8	38.1	34.7	-3.4	-2.0	-1.4
283	58			21.3	39.5	34.0	-5.5	-2.0	-3.5
556	58			17.1	35.3	36.4	1.1	-2.0	3.1
445	58			19.2	37.4	34.5	-2.9	-2.0	-0.9
309	58			20.6	38.9	37.1	-1.8	-2.0	0.2
532	58			21.5	39.7	36.9	-2.8	-2.0	-0.8
157	59			20.6	38.8	36.9	-1.8	-2.0	0.2
596	64			19.8	38.0	35.3	-2.7	-2.0	-0.7
264	65			20.5	38.7	36.4	-2.4	-2.0	-0.4
114	66			21.7	40.0	34.5	-5.4	-2.0	-3.4
56	66			22.9	41.1	33.8	-7.4	-2.0	-5.4
59	66			22.4	40.6	34.8	-5.8	-2.0	-3.8
563	66			18.5	36.7	37.9	1.2	-2.0	3.2
593	66			18.9	37.1	37.3	0.2	-2.0	2.2
443	66			18.4	36.6	36.0	-0.6	-2.0	1.4
527	66			21.5	39.8	34.5	-5.3	-2.0	-3.3
39	66			21.9	40.1	33.6	-6.6	-2.0	-4.6
636	66			19.7	37.9	37.7	-0.2	-2.0	1.8
471	66			17.0	35.3	37.5	2.2	-2.0	4.2
67	67			22.7	40.9	34.1	-6.8	-2.0	-4.8
630	67			20.9	39.2	36.4	-2.8	-2.0	-0.8
Average	61						-1.5	-2.0	0.5

Table D.08 Tonality Assessment Table - 10.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
599	58			19.2	37.4	37.1	-0.3	-2.0	1.7
552	58			17.8	36.1	35.8	-0.2	-2.0	1.8
462	58			18.8	37.0	34.3	-2.7	-2.0	-0.7
257	58			19.3	37.6	35.6	-2.0	-2.0	0.0
249	58			18.4	36.6	35.9	-0.7	-2.0	1.3
188	58			19.4	37.6	34.5	-3.1	-2.0	-1.1
467	58			17.5	35.7	36.5	0.8	-2.0	2.8
381	58			20.5	38.7	37.7	-1.1	-2.0	0.9
440	58			20.2	38.4	37.6	-0.8	-2.0	1.2
372	58			19.5	37.7	36.5	-1.2	-2.0	0.8
391	58			19.8	38.0	36.3	-1.7	-2.0	0.3
578	58			20.0	38.3	36.7	-1.6	-2.0	0.4
451	58			19.5	37.7	35.4	-2.3	-2.0	-0.3
526	58			21.4	39.6	36.7	-3.0	-2.0	-1.0
397	58			19.7	37.9	38.1	0.2	-2.0	2.2
373	58			18.6	36.8	37.1	0.3	-2.0	2.3
246	58			20.1	38.4	35.8	-2.6	-2.0	-0.6
369	58			20.1	38.4	36.4	-2.0	-2.0	0.0
436	58			19.2	37.4	36.6	-0.8	-2.0	1.2
472	58			17.5	35.7	35.4	-0.3	-2.0	1.7
349	58			19.1	37.4	35.8	-1.6	-2.0	0.4
474	58			19.1	37.3	36.0	-1.3	-2.0	0.7
254	58			18.4	36.7	36.8	0.1	-2.0	2.1
428	58			18.6	36.9	36.7	-0.2	-2.0	1.8
267	58			21.3	39.6	35.4	-4.2	-2.0	-2.2
199	58			22.9	41.1	34.0	-7.1	-2.0	-5.1
396	58			20.0	38.2	37.1	-1.1	-2.0	0.9
465	58			19.1	37.3	36.3	-1.0	-2.0	1.0
150	59			20.5	38.7	35.5	-3.2	-2.0	-1.2
378	65			20.5	38.8	35.8	-3.0	-2.0	-1.0
580	65			18.0	36.3	36.2	-0.1	-2.0	1.9
312	66			19.2	37.4	35.5	-2.0	-2.0	0.1
595	66			20.2	38.5	37.4	-1.1	-2.0	0.9
459	66			19.5	37.7	36.6	-1.1	-2.0	0.9
99	66			22.3	40.6	34.0	-6.6	-2.0	-4.6
196	66			20.0	38.2	35.6	-2.6	-2.0	-0.6
120	66			21.9	40.1	32.1	-8.0	-2.0	-6.0
238	66			20.8	39.0	37.0	-2.0	-2.0	0.0
452	66			20.7	38.9	33.4	-5.6	-2.0	-3.6
117	66			23.1	41.3	33.7	-7.6	-2.0	-5.6
600	67			19.5	37.7	37.5	-0.3	-2.0	1.7
237	67			19.6	37.8	37.4	-0.4	-2.0	1.6
323	71			21.1	39.3	39.3	0.0	-2.0	2.0
Average	61						-1.6	-2.0	0.4

Table D.09 Tonality Assessment Table - 11 m/s

Project: Cedar Point Wind Power Project - Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
294	58			19.4	37.7	36.9	-0.8	-2.0	1.3
427	58			18.4	36.7	35.4	-1.3	-2.0	0.7
584	58			20.2	38.5	37.0	-1.5	-2.0	0.5
555	58			17.6	35.8	37.2	1.4	-2.0	3.4
275	58			20.4	38.7	36.4	-2.3	-2.0	-0.3
256	58			18.6	36.9	35.6	-1.3	-2.0	0.7
455	58			21.5	39.7	36.7	-3.0	-2.0	-1.0
346	58			17.8	36.0	36.6	0.6	-2.0	2.6
107	58			22.1	40.4	33.2	-7.2	-2.0	-5.2
332	58			21.2	39.5	35.4	-4.1	-2.0	-2.1
274	58			19.6	37.8	35.9	-1.9	-2.0	0.1
272	58			18.6	36.9	37.6	0.7	-2.0	2.7
152	58			20.7	38.9	34.6	-4.3	-2.0	-2.3
370	58			20.6	38.8	37.2	-1.6	-2.0	0.4
219	58			19.5	37.7	35.1	-2.6	-2.0	-0.6
562	58			18.4	36.7	36.7	0.0	-2.0	2.0
385	58			19.1	37.3	36.6	-0.7	-2.0	1.3
376	58			20.3	38.5	36.3	-2.2	-2.0	-0.2
414	58			20.5	38.7	36.2	-2.5	-2.0	-0.5
444	58			18.9	37.2	37.0	-0.1	-2.0	1.9
434	58			19.3	37.6	37.2	-0.3	-2.0	1.7
191	58			19.1	37.3	35.8	-1.5	-2.0	0.5
330	58			20.4	38.7	36.0	-2.7	-2.0	-0.7
218	58			20.2	38.4	36.1	-2.3	-2.0	-0.3
631	58			20.7	39.0	34.4	-4.5	-2.0	-2.5
392	58			19.7	38.0	37.4	-0.6	-2.0	1.4
379	58			20.9	39.2	36.3	-2.9	-2.0	-0.9
390	58			20.0	38.2	35.4	-2.8	-2.0	-0.8
217	58			20.7	39.0	35.5	-3.5	-2.0	-1.5
550	58			17.7	35.9	36.6	0.7	-2.0	2.7
544	58			20.4	38.7	34.6	-4.0	-2.0	-2.0
342	58			18.7	36.9	36.3	-0.6	-2.0	1.4
432	58			16.9	35.2	36.0	0.9	-2.0	2.9
220	58			20.5	38.7	33.6	-5.2	-2.0	-3.2
306	58			20.8	39.1	36.7	-2.4	-2.0	-0.4
353	58			20.0	38.2	37.0	-1.2	-2.0	0.8
393	58			20.0	38.2	36.5	-1.8	-2.0	0.2
148	58			19.9	38.1	36.7	-1.4	-2.0	0.6
91	66			20.4	38.7	36.3	-2.4	-2.0	-0.4
126	66			22.3	40.5	34.7	-5.9	-2.0	-3.9
234	66			19.9	38.2	37.5	-0.7	-2.0	1.3
569	66			19.5	37.7	36.6	-1.1	-2.0	0.9
122	66			22.3	40.5	32.7	-7.8	-2.0	-5.8
79	66			22.0	40.2	35.8	-4.5	-2.0	-2.5
435	66			19.5	37.8	37.2	-0.6	-2.0	1.4
42	66			22.3	40.5	32.5	-8.0	-2.0	-6.0
545	67			18.3	36.6	34.1	-2.5	-2.0	-0.5
201	67			20.6	38.8	35.4	-3.4	-2.0	-1.4
248	67			19.6	37.8	36.2	-1.6	-2.0	0.4
Average	60						-1.8	-2.0	0.2

Table D.10 Tonality Assessment Table - 11.5 m/s

Project: Cedar Point Wind Power Project- Turbine CP209 - IEC 61400-11 Measurement
 Report ID: 15039.00.T209.RP3

Page 1 of 1
 Created on: 3/7/2018

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
355	58			21.1	39.4	36.3	-3.1	-2.0	-1.1
289	58			19.2	37.5	37.5	0.1	-2.0	2.1
420	58			19.5	37.7	37.7	0.0	-2.0	2.0
113	58			22.9	41.2	30.1	-11.0	-2.0	-9.0
348	58			18.7	37.0	36.8	-0.1	-2.0	1.9
345	58			17.9	36.2	36.1	0.0	-2.0	2.0
574	58			19.3	37.5	36.8	-0.7	-2.0	1.3
183	58			19.8	38.1	35.6	-2.5	-2.0	-0.5
178	58			21.4	39.7	32.3	-7.4	-2.0	-5.4
292	58			20.0	38.2	36.7	-1.5	-2.0	0.5
383	58			18.2	36.5	36.3	-0.2	-2.0	1.8
398	58			20.3	38.5	35.9	-2.6	-2.0	-0.6
195	58			20.6	38.8	35.3	-3.5	-2.0	-1.5
350	58			18.7	37.0	37.5	0.6	-2.0	2.6
273	58			19.1	37.4	35.7	-1.6	-2.0	0.4
387	58			19.4	37.7	36.3	-1.4	-2.0	0.6
358	58			19.5	37.8	37.6	-0.1	-2.0	1.9
255	58			18.3	36.5	35.4	-1.2	-2.0	0.8
441	58			19.5	37.7	36.8	-0.9	-2.0	1.1
416	58			20.8	39.0	35.7	-3.4	-2.0	-1.3
240	58			19.8	38.1	36.8	-1.3	-2.0	0.7
78	66			21.3	39.5	33.6	-5.9	-2.0	-3.9
127	66			21.7	39.9	35.2	-4.7	-2.0	-2.7
52	66			22.7	40.9	35.5	-5.4	-2.0	-3.4
421	67			19.0	37.2	36.4	-0.8	-2.0	1.2
Average	59						-1.7	-2.0	0.3

Appendix E Measurement Data

Appendix F

Note on anemometer position with IEC 61400-11 Ed 2.1 and Ed 3.0

Note N6.040.17

Note on anemometer position with IEC 61400-11 editions 2.1 and 3.0

Project number: 35.6539.01

Project manager: Bo Søndergaard

Author: Bo Søndergaard

Date: 7/11/2017

Controlled by: -

To : Aercoustics Engineering Limited
Att.: Payam Ashtiani

From : Bo Søndergaard

1. Purpose

In the capacity of convenor for Maintenance Team 11, the workgroup in charge of IEC 61400-11, since 2006, I have been asked to provide background information, and comment on the consequences of changing the anemometer position when going from edition 2.1 to edition 3, and the recommended method for using measurements based on edition 2.1 for an analysis with edition 3.

2. Comment

There are several differences between IEC 61400-11 standard edition 2.1 (November 2006) and edition 3.0 (November 2012). In particular, the general data treatment procedures for noise levels, and the tonality assessment were changed to keep up with the changes in wind turbine design at the time.

However, since edition 1.0 (1998), very few changes have been made to the IEC 61400-11 standard with respect to the measurement setup. In edition 1.0 the prescribed position of the anemometer was upwind (2 to 4 rotor diameters) as it was allowed to use the anemometer for determination of the standardized wind speed with the wind turbine running. At that time the distances were smaller and this setup is maintained in Annex F on small wind turbines in edition 3. Editions 2.0 and 2.1, still allowed such use of the anemometer

In Germany, modified versions of IEC 61400-11 edition 2 were introduced by the FGW. In revision 15 (from 2004), using the power for determination of the standardized wind speed was mandatory. In revision 16 (from 2005), it was stated that the position of the anemometer can deviate from the requirements in IEC 61400-11 edition 2, without specifying position requirements. Germany has had a strong influence on the development of the IEC 61400-11 standard through the experience from several measuring companies and German authorities. The decision to allow alternative positions for the anemometer is very representative of the situation. It is difficult to set up general requirements for the position of the anemometer that works at all sites. As such, it makes sense to allow for an expert


judgement on the anemometer position in a given situation. In the Danish regulations, it is stated that the anemometer has to be close to the wind turbine in a position where neither the wind turbine nor objects in the terrain is expected to influence the wind speed measurements.

The German and Danish considerations on the position of the anemometer is based on the fact that the dominating background noise at the microphone position can be more or less dependent on wind speed; and can be generated by vegetation upwind, downwind or to the side of the wind turbine. This is often reflected in background noise with a weak dependence on wind speed.

Maintenance Team 11, responsible for revising IEC 61400-11, discussed this issue and there was a strong support from the measurement institutes for using the nacelle anemometer for background noise measurements. In most cases, this would give a reasonable correlation between wind speed and background noise. The nacelle anemometer is not influenced by terrain and represents, to a reasonable degree, the wind in the surroundings. However, the manufacturers argued that the nacelle anemometer might not be a part of future designs and could not be guaranteed. There was a general agreement that it was difficult to decide on an optimum position, but in most cases, downwind and to the side would make sense, resulting in Figure 5 of edition 3.0. The position of the anemometer is not considered an important issue and the wording is "guidance" and "acceptable" and not a stronger wording like "shall". This is a deliberate decision by the Maintenance Team 11 to ensure flexibility when other choices make more sense.

The recommended method when using measurements made according to IEC 61400-11 edition 2.1 for analysis with IEC 61400-11 edition 3.0 is to use the nacelle anemometer for the background noise. This will work well in most cases. Alternatively, to use the measured wind speed at 10 m height if there is no strong influence from the background noise (e.g. when signal to noise ratio is better than 6 dB).

SWECO Danmark A/S



Bo Søndergaard

Acoustica

Appendix G Information for Regulator

E-Audit Checklist

(2017 Compliance Protocol AF5): E-Audit checklist**Wind Energy Project – Screening Document – Acoustic Audit Report – Emission IEC61400-11 Standard
Information Required in the Acoustic Audit Report – Immission**

Item #	Description	Complete?	Comment
1	Characterization of the wind turbine Items 1 to 26; IEC61400-11:2013, Section 10.2	✓	
2	Physical environment Items 27 to 33; IEC61400-11:2013, Section 10.3, Physical Environment	✓	
3	Measurement instrumentation Items 34 to 39; IEC61400-11:2013, Section 10.4, Instrumentation	✓	
4	Acoustic data Items 40 to 52; IEC61400-11:2013, Section 10.5, Acoustic Data	✓	
5	Non-acoustic data Items 50 to 53, and 56; IEC61400-11:2003 Section 10.6, Non-Acoustic Data Items 59 and 60; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations	✓	
6	Uncertainty the apparent sound power level at integer wind speeds one-third octave band spectrum of the noise at the reference position at each integer wind speed the Tonality of the sound emissions of the wind turbine measured at the reference position	✓	
7	Additional information Item 60; NPC-233, Section 10, Report Format, bullet point number 4, Conclusions and Recommendations Item 61; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 8, All necessary and supporting calculations Item 62; NPC-233, Section 12.3, Acoustic Audit – Acoustical Data, bullet point number 3, Details of measurement procedure	✓	All data Excel sheet provided
8	Items 68 to 72; IEC61400-11:2013, Section 10.5, Acoustic Data	⊙	Items 68 to 72 acoustic data as per IEC 61400-11 standard are optional; low frequency noise, infrasound, impulsivity, amplitude modulation not reported
9	Non-acoustic data Items 73 to 74 are from IEC61400-11:2013, Section 10.6, Non-Acoustic Data	⊙	Items 73 to 74 non-acoustic data as per IEC 64100-11 standard are optional; turbulence intensity during acoustic meeasurements not reported

Sample Calculation

Allowed Range from Power Curve and Required Wind Speeds

Sample Calculation: Allowed range of power curve and required wind speeds

Project: Cedar Point Wind Power Project - Turbine WTG10 (CP209) - IEC 61400-11 Measurement

Report ID: 15039.00.T209.RP3

Page 1 of 1

Created on: 3/7/2018

Power Curve & Required Wind Speeds		
Power Curve Tolerance	1%	
Min allowable range	1.5	m/s
Max allowable range	9.5	m/s
Power Output	2030	kW
85% Power	1725.5	kW
Corresponding wind speed	8.67	m/s
Minimum bin	7.0	m/s
Maximum bin	11.5	m/s

Hub Wind Speed (m/s)	Power [kW]	+ value = acceptable slope of power curve
0	0	-40.6
1	0	-40.6
2	0	25.4
3	66	64.4
4	171	138.4
5	350	229.4
6	620	333.4
7	994	419.4
8	1454	367.4
9	1862	102.4
10	2005	-16.6
11	2029	-39.6
12	2030	-40.6
13	2030	-40.6
14	2030	-40.6
15	2030	-40.6
16	2030	-40.6
17	2030	-40.6
18	2030	-40.6
19	2030	-40.6
20	2030	-40.6
21	2030	-40.6
22	2030	-40.6
23	2030	-40.6
24	2030	-40.6
25	2030	-40.6

Sample Calculation

K_{nac} and K_z

[as per IEC 61400-11 Edition 3.0 Section 8.2.1.2 and Section 8.2.2]

SAMPLE CALCULATION

This calculation example demonstrates the calculation of nacelle k-factor as per IEC 61400-11 Edition 3.0 section 8.2.1.2

Sample calculations have been based on measurement data collected and reported for Cedar Point Wind Power Project (Report ID: 15039.00.CP209.R3)

For all data points with power levels from the allowed range of the power curve, the average value of the ratio of the wind speed derived from the power curve $V_{p,n}$ and the measured nacelle wind speed $V_{nac,m}$, k_{nac} , is derived as per equation (1). Information to calculate k_{nac} is provided in Table 1.

$$k_{nac} = \frac{1}{n} \left(\sum_{i=1}^n \left(\frac{v_{p,n}}{v_{nac,m}} \right)_i \right) \quad (1)$$

where

$V_{nac,m}$ is measured nacelle wind speed

K_{nac} is nacelle k-factor

$V_{p,n}$ is wind speed derived from the power curve

$k_{nac} = 0.9854$

SAMPLE CALCULATION

This calculation example demonstrates the calculation of nacelle k-factor as per IEC 61400-11 Edition 3.0 section 8.2.1.2

Sample calculations have been based on measurement data collected and reported for Cedar Point Wind Power Project (Report ID: 15039.00.CP209.R3)

For all data points with power levels from the allowed range of the power curve, the average value of the ratio of the wind speed derived from the power curve $V_{p,n}$ and the measured wind speed $V_{z,m}$, k_z , is derived as per equation (1) Information to calculate k_z is provided in Table 1.

$$k_z = \frac{1}{n} \left(\sum_{i=1}^n \left(\frac{v_{p,n}}{v_{z,m}} \right)_i \right) \quad (1)$$

where

$V_{p,n}$ is wind speed derived from power curve

K_z is Background k-factor

$V_{z,n}$ is measured 10m wind speed

$k_z = 1.2254$

Sample Calculation

Standardized Wind Speed Through Power Curve

Standardized Wind Speed with Nacelle Anemometer

[as per IEC 61400-11 Edition 3.0 Section 8.2.1.1 and Section 8.2.1.2]

SAMPLE CALCULATION

This calculation example demonstrates the calculation of standardized wind speed through power curve and the calculation of standardized wind speed with Nacelle anemometer as per IEC 61400-11 Edition 3.0 section 8.2.1.1 and section 8.2.1.2

Sample calculations have been based on measurement data collected and reported for Cedar Point Wind Power Project (Report ID: 15039.00.T209.R3) for data points collected during Turbine ON measurements [Data point #5 and #1]

8.2.1.1 Determination of Wind Speed through power curve (m/s)

Step 1: Determine Acceptable Range of Power Curve

The power curve relates the power to the wind speed at hub height. The wind speed is determined from the measured electric power. Correlation between measured sound level and measured electric power is very high for the allowed intervals of the power curve, see Equation (3). The intervals on the power curve that can be used are all intervals where no duplicated values exist and the slope of the power curve including the uncertainty is positive. The demand on the slope of the power curve is satisfied for any interval on the power curve, where the following is fulfilled:

$$(P_{k+1} - P_{tol}) - (P_k + P_{tol}) > 0 \quad (3)$$

where

k is the wind speed bin number of the power curve;

P_k is the power curve value at wind bin k;

P_{tol} is the tolerance on the power reading, typical values for P_{tol} are 1 to 5% of maximum value

The Acceptable Range of the power curve based on the slope of the power curve is highlighted in table 1.

Step2: Determine Standardized Wind Speed from linear interpolation from power curve for Data Point # 5

Average Active Power measured for Data Point #5 (x) = 2022 kW

$$y = y_0 + (x - x_0) \frac{y_1 - y_0}{x_1 - x_0} = \frac{y_0(x_1 - x) + y_1(x - x_0)}{x_1 - x_0}$$

$y_0 =$	10	m/s
$x_0 =$	2005	kW
$y_1 =$	11	m/s
$x_1 =$	2029	kW
$x =$	2022	kW
$y =$	10.70	m/s

8.2.1.2 Determination of Wind Speed with Nacelle Anemometer

For all data points with power levels from the allowed range of the power curve, the average value of the ratio of the wind speed derived from the power curve $V_{P,n}$ and the measured nacelle wind speed $V_{nac,m}$, K_{nac} is derived. This value is applied to the measured nacelle wind speed for the data points with power levels outside the allowed range of the power curve to derive the normalised wind speed using Equation (4).

$$V_{nac,n} = K_{nac} V_{nac,m} \quad (4)$$

$V_{nac,m}$ is the wind speed measured with the nacelle anemometer;

$V_{nac,n}$ is the normalised wind speed from the nacelle anemometer, corrected to hub height

Determine Standardized Wind Speed using eq(4) for Data Point #1

$K_{nac} =$	0.9854	
$V_{nac,m} =$	12.88	m/s
$V_{nac,n} =$	12.69	m/s

Table 1 - Power Curve and Acceptable Range of Power Curve

Hub Wind Speed (m/s)	Power [kW]	+ value = acceptable slope of power curve
0	0	-40.6
1	0	-40.6
2	0	25.4
3	66	64.4
4	171	138.4
5	350	229.4
6	620	333.4
7	994	419.4
8	1454	367.4
9	1862	102.4
10	2005	-16.6
11	2029	-39.6
12	2030	-40.6
13	2030	-40.6
14	2030	-40.6
15	2030	-40.6
16	2030	-40.6
17	2030	-40.6
18	2030	-40.6
19	2030	-40.6
20	2030	-40.6
21	2030	-40.6
22	2030	-40.6
23	2030	-40.6
24	2030	-40.6
25	2030	-40.6

Table 2 - Power Curve & Required Wind Speeds

Power Curve & Required Wind Speeds		
Power Curve Tolerance	1%	
Acceptable range min	2	m/s
Acceptable range max	9	m/s
Min allowable range	1.5	m/s
Max allowable range	9.5	m/s
Power Output	2030	kW
85% Power	1725.5	kW
Corresponding wind speed	8.67	m/s
Minimum bin	7.0	m/s
Maximum bin	11.5	m/s

Table 3 - Nacelle K-factor and Background K-factor

Environmental Details		
k_nac	0.9854	
k_Z	1.2254	

Calibration Certificates



SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA

Tel 802.316.4368 · Fax 802.735.9106 · www.sohwind.com

CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 16.US1.06097

Date of issue: July 5, 2016

Type: Vaisala Weather Transmitter, WXT520

Serial number: K2420011.0deg

Manufacturer: VAISALA Oyj, PI 26, FIN-00421 Helsinki, Finland

Client: Aercoustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada

Anemometer received: June 28, 2016

Anemometer calibrated: 10:48 July 5, 2016

Calibrated by: mej

Procedure: MEASNET, IEC 61400-12-1:2005(E) Annex F

Certificate prepared by: ejf

Approved by: Calibration engineer, rds

Calibration equation obtained: $v \text{ [m/s]} = 1.01362 \cdot f \text{ [m/s]} + -0.00805$

Standard uncertainty, slope: 0.00170

Standard uncertainty, offset: -2.27147

Covariance: -0.0000296 (m/s)²/m/s



Coefficient of correlation: $\rho = 0.999984$

Absolute maximum deviation: 0.037 m/s at 10.080 m/s

Barometric pressure: 995.5 hPa

Relative humidity: 40.4%

Succession	Velocity pressure, q, [Pa]	Temperature in wind tunnel [°C]	Temperature in d.p. box [°C]	Wind velocity, v, [m/s]	Anemometer Output, f, [m/s]	Deviation, d, [m/s]	Uncertainty u_c (k=2) [m/s]
2	10.39	28.4	27.9	4.309	4.252	0.008	0.025
4	14.78	28.5	28.0	5.133	5.100	-0.028	0.025
6	20.54	28.5	28.0	6.008	5.948	-0.013	0.027
8	27.78	28.5	28.0	7.033	6.916	0.030	0.030
10	36.94	28.5	28.0	8.103	8.000	0.002	0.033
12	46.48	28.5	28.0	9.099	8.984	0.001	0.036
13-last	57.18	28.5	28.0	10.080	9.916	0.037	0.039
11	69.26	28.5	28.0	11.099	10.952	0.007	0.042
9	82.18	28.5	28.0	12.071	11.952	-0.035	0.046
7	95.15	28.5	28.0	12.995	12.835	-0.007	0.049
5	110.58	28.5	28.0	14.040	13.884	-0.024	0.052
3	128.53	28.5	28.0	15.117	14.919	0.003	0.056
1-first	144.29	28.4	27.9	16.024	15.797	0.020	0.059



AC-1746



EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.004
2254	Control cup anemometer
-	Mounting tube, D = 30 mm
TT004	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY003	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRW1	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Essco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.



Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.

UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

Certificate number: 16.US1.06097




SOH Wind Engineering LLC

141 Leroy Road · Williston, VT 05495 · USA
Tel 802.316.4368 · Fax 802.735.9106 · www.sohwind.com



CERTIFICATE FOR CALIBRATION OF SONIC ANEMOMETER

Certificate number: 16.US1.06098 **Date of issue:** July 5, 2016
Type: Vaisala Weather Transmitter, WXT520 **Serial number:** K2420011.90deg
Manufacturer: VAISALA Oyj, PI 26, FIN-00421 Helsinki, Finland
Client: Aercoustics Engineering Ltd., 50 Ronson Dr, Suite 165, Toronto, ON M9W 1B3, Canada
Anemometer received: June 28, 2016 **Anemometer calibrated:** 11:08 July 5, 2016
Calibrated by: mej **Procedure:** MEASNET, IEC 61400-12-1:2005(E) Annex F
Certificate prepared by: cjf **Approved by:** Calibration engineer, rds

Calibration equation obtained: $v \text{ [m/s]} = 0.99840 \cdot f \text{ [m/s]} + 0.23389$ 

Standard uncertainty, slope: 0.00605 **Standard uncertainty, offset:** 0.27227
Covariance: -0.0003601 (m/s)²/m/s **Coefficient of correlation:** $\rho = 0.999799$
Absolute maximum deviation: 0.143 m/s at 12.071 m/s
Barometric pressure: 995.3 hPa **Relative humidity:** 40.2%

Succession	Velocity pressure, q, [Pa]	Temperature in wind tunnel [°C]	d.p. box [°C]	Wind velocity, v, [m/s]	Anemometer Output, f, [m/s]	Deviation, d, [m/s]	Uncertainty u_c (k=2) [m/s]
2	10.48	28.6	28.0	4.309	4.100	-0.018	0.025
4	14.88	28.6	28.0	5.133	4.965	-0.057	0.026
6	20.41	28.6	28.0	6.008	5.823	-0.039	0.027
8	27.86	28.6	28.0	7.033	6.752	0.058	0.030
10	36.96	28.6	28.0	8.103	7.800	0.082	0.033
12	46.52	28.6	28.0	9.099	8.739	0.140	0.036
13-last	57.08	28.6	28.0	10.080	9.900	-0.038	0.039
11	69.14	28.6	28.0	11.099	10.874	0.009	0.042
9	82.16	28.6	28.0	12.071	12.000	-0.143	0.046
7	94.99	28.6	28.0	12.995	12.881	-0.099	0.049
5	110.48	28.6	28.0	14.040	13.823	0.006	0.052
3	128.65	28.6	28.0	15.117	14.848	0.059	0.056
1-first	144.01	28.5	28.0	16.024	15.774	0.041	0.058



AC-1746



EQUIPMENT USED

Serial Number	Description
Njord 1	Wind tunnel, blockage factor = 1.004
2254	Control cup anemometer
-	Mounting tube, D = 30 mm
TT004	Summit RT-AUI, wind tunnel
TP001	Summit RT-AUI, differential pressure box
DP006	Setra Model 239 pressure transducer
HY003	Dwyer Instruments RHP-2D20 humidity transmitter
BP002	Setra Model 278 barometer
PL8	Pitot tube
XB002	Computer Board. 16 bit A/D data acquisition board
9PRZRWI	PC dedicated to data acquisition

Traceable calibrations of the equipment are carried out by external accredited institutions: Atlantic Scale, Essco Calibration Labs & Furness Controls. A real-time analysis module within the data acquisition software detects pulse frequency.



Photo of the wind tunnel setup. The cross-sectional area is 2.5 x 2.5 m.


UNCERTAINTIES

The documented uncertainty is the total combined uncertainty at 95% confidence level ($k=2$) in accordance with EA-4/02. The uncertainty at 10 m/s comply with the requirements in the IEC 61400-12-1:2005 procedure. See Document US.12.01.004 for further details.

Certificate number: 16.US1.06098

Customer: AEROCOUSTICS ENGINEERING LTD
50 RONSON DRIVE
SUITE 165
TORONTO, ON M9W 1B3

PO Number: 2016.06.27C



Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Manufacturer: Nokeval
Model Number: 7470
Description: Serial to Analog Converter
Serial Number: A165152
ID: NONE

As-Found: In Tolerance
As-Left: In Tolerance

Calibration Date: July 11, 2016
Due Date: July 11, 2018

Calibrated To: Manufacturer Specification
Calibration Procedure: 1-AC58014-0

Transcat Calibration Laboratories have been audited and found in compliance with ISO/IEC 17025:2005. Accredited calibrations performed within the Lab's Scope of Accreditation are indicated by the presence of the Accrediting Body's Logo and Certificate Number on this Certificate of Calibration. Any measurements on an accredited calibration not covered by that Lab's Scope of Accreditation are listed in the notes section of the certificate. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, SCC, NRC, CLAS, ANAB or any agency of the Federal Government. NVLAP, NIST, SCC, NRC, CLAS or ANAB do not guarantee the accuracy of an individual calibration by accredited laboratories.

Transcat calibrations, as applicable, are performed in compliance with the requirements of the Transcat Quality Manual Revision I, ISO 9001:2008, ANSI/NCSL Z540 1-1994 (R2002), and ISO 10012:2003. When specified contractually, the requirements of ISO TS16949:2009, 10CFR21, 10CFR50 App. B and ASME NQA-1:2012 are also covered. Complete records of work performed are maintained by Transcat and are available for inspection. Laboratory standards used in the performance of this calibration are shown on the Supplemental Report.

Transcat documents the traceability of measurements to the SI units through the National Institute of Standards and Technology (NIST), or the National Research Council of Canada (NRC), or other recognized national measurement institutes (NMI) that are signatories to the CIPM Mutual Recognition Arrangement, or accepted fundamental and/or natural physical constants, or by the use of specified methods, consensus standards or ratio type measurements. Documentation supporting traceability information is available for review at a Transcat facility. The measured quantity and the measurement uncertainty are required for further dissemination of traceability.

Uncertainties are reported with a coverage factor $k=2$, providing a level of confidence of approximately 95%. All calibrations have been performed using processes having a TUR of 4:1 or better (3:1 for mass calibrations), unless otherwise noted on the Supplemental Report. The Test Uncertainty Ratio (TUR) is calculated in accordance with NCSL International RP-18. For mass calibrations: Conventional mass referenced to 8.0 g/cm³.

The results in this report relate only to the item calibrated or tested, and the determination of in or out of tolerance is specific to the model/serial no. referenced above based on the tolerances shown on the supplemental report; these tolerances are either the original equipment manufacturer's (OEM's) warranted specifications or the client's requested specifications. Any number of factors can cause a unit to drift out of tolerance at any time following its calibration. Limitations on the uses of this instrument are detailed in the OEM's operating instructions. This certificate may not be reproduced except in full, without the written approval of Transcat. Additional information, if applicable may be included on separate report(s).

Notes:

SCC Accreditation & Design Mark is an Official Mark of the Standards Council of Canada, used under license.

Calibrated At:
916 Gateway
Burlington, ON L7L 5K7

Facility Responsible:
916 Gateway
Burlington, ON L7L 5K7
800-828-1470

Calibrated By:
 Digitally Signed By
Lawrence Loi
Date: July 11, 2016
Lawrence Loi
Calibration Technician

Reviewed By:
 Digitally Signed By
Robert Whittaker
Date: July 11, 2016
Robert Whittaker
Lab Manager

Unit Barcode: 901B0165859

Date Received: June 27, 2016

Customer: AEROCOUSTICS ENGINEERING LTD

PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Manufacturer: Nokeval

Model Number: 7470

Description: Serial to Analog Converter

Serial Number: A165152

ID: NONE

Service Type: R9

Calibration Date: Jul 11, 2016

Date Due: Jul 11, 2018

Calibration Procedure: 1-AC58014-0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	Cal Process		Units	TUR
						Uncertainty	Measurement Uncertainty		
DC Current % Source - 4-20mA Ch #1									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	4.001 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.998 mA	2.6e-004	1.9e-003	mA	61.5 : 1
	50%	±(0.1% Span)	11.984	12.016	12.002 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.000 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA	1.4e-003	2.3e-003	mA	11.4 : 1

DC Current % Source - 4-20mA Ch #2									
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.996 mA	1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	7.996 mA	2.6e-004	1.9e-003	mA	61.5 : 1
	50%	±(0.1% Span)	11.984	12.016	11.997 mA	1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.003 mA	1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA	1.4e-003	2.3e-003	mA	11.4 : 1

The column labeled Cal Process Uncertainty(CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU
 Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Revision 0

Field not applicable. (P = Pass, F = Fail)

Calibration Lab Data Report - Page 1 of 6

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

F0177R2 03/22/16

Customer: AEROCOUSTICS ENGINEERING LTD

PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O T	Cal Process Uncertainty	Measurement t Uncertainty	Units	TUR
DC Current % Source - 4-20mA Ch #3										
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	3.997 mA		1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	8.000 mA		2.6e-004	1.9e-003	mA	61.5 : 1
	50%	±(0.1% Span)	11.984	12.016	12.000 mA		1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	15.999 mA		1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA		1.4e-003	2.3e-003	mA	11.4 : 1
DC Current % Source - 4-20mA Ch #4										
4 - 20mA	0%	±(0.1% Span)	3.984	4.016	4.002 mA		1.6e-004	1.9e-003	mA	100.0 : 1
	25%	±(0.1% Span)	7.984	8.016	8.000 mA		2.6e-004	1.9e-003	mA	61.5 : 1
	50%	±(0.1% Span)	11.984	12.016	12.000 mA		1.1e-003	2.2e-003	mA	14.5 : 1
	75%	±(0.1% Span)	15.984	16.016	16.004 mA		1.3e-003	2.3e-003	mA	12.3 : 1
	100%	±(0.1% Span)	19.984	20.016	20.001 mA		1.4e-003	2.3e-003	mA	11.4 : 1
DC Current % Source - 0-20mA Ch #1										
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.003 mA		9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	5.000 mA		1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.000 mA		3.1e-004	2.3e-003	mA	64.5 : 1
	75%	±(0.1% Span)	14.980	15.020	14.999 mA		1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.001 mA		1.4e-003	2.7e-003	mA	14.3 : 1

The column labeled Cal Process Uncertainty (CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU
 Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Revision 0

Field not applicable. (P = Pass, F = Fail)

Calibration Lab Data Report - Page 2 of 6

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

F0177R2 03/22/16

Customer: AEROCOUSTICS ENGINEERING LTD

PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O		Units	TUR
						Process Uncertainty	Measurement Uncertainty		
DC Current % Source - 0-20mA Ch #2									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.998 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	9.996 mA	3.1e-004	2.3e-003	mA	64.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.000 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.001 mA	1.4e-003	2.7e-003	mA	14.3 : 1

DC Current % Source - 0-20mA Ch #3									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	4.998 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.001 mA	3.1e-004	2.3e-003	mA	64.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.001 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.001 mA	1.4e-003	2.7e-003	mA	14.3 : 1

DC Current % Source - 0-20mA Ch #4									
0 - 20mA	0%	±(0.1% Span)	-0.020	0.020	0.000 mA	9.2e-007	2.3e-003	mA	100.0 : 1
	25%	±(0.1% Span)	4.980	5.020	5.000 mA	1.9e-004	2.3e-003	mA	100.0 : 1
	50%	±(0.1% Span)	9.980	10.020	10.003 mA	3.1e-004	2.3e-003	mA	64.5 : 1
	75%	±(0.1% Span)	14.980	15.020	15.000 mA	1.2e-003	2.6e-003	mA	16.7 : 1
	100%	±(0.1% Span)	19.980	20.020	20.001 mA	1.4e-003	2.7e-003	mA	14.3 : 1

The column labeled Cal Process Uncertainty (CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU
 Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT

Revision 0

Field not applicable. (P = Pass, F = Fail)

Calibration Lab Data Report - Page 3 of 6

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

F0177R2 03/22/16

Customer: AEROCOUSTICS ENGINEERING LTD
 PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O Q T	Cal Process Uncertainty	Measurement t Uncertainty	Units	TUR
DC Voltage % Source - 0-5V Ch#1										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0008 V		5.8e-007	5.8e-004	V	100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	0.9996 V		5.6e-006	5.8e-004	V	100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9987 V		1.1e-005	5.8e-004	V	100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	3.0009 V		1.6e-005	5.8e-004	V	100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	4.0007 V		2.1e-005	5.8e-004	V	100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	5.0003 V		2.6e-005	5.8e-004	V	100.0 : 1

DC Voltage % Source - 0-5V Ch#2										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0011 V		5.8e-007	5.8e-004	V	100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	1.0001 V		5.6e-006	5.8e-004	V	100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9989 V		1.1e-005	5.8e-004	V	100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	3.0009 V		1.6e-005	5.8e-004	V	100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	4.0003 V		2.1e-005	5.8e-004	V	100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	4.9998 V		2.6e-005	5.8e-004	V	100.0 : 1

DC Voltage % Source - 0-5V Ch#3										
0 -5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0016 V		5.8e-007	5.8e-004	V	100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	0.9994 V		5.6e-006	5.8e-004	V	100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	1.9994 V		1.1e-005	5.8e-004	V	100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	3.0000 V		1.6e-005	5.8e-004	V	100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	4.0007 V		2.1e-005	5.8e-004	V	100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	5.0014 V		2.6e-005	5.8e-004	V	100.0 : 1

The column labeled Cal Process Uncertainty(CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU
 Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Revision 0

Field not applicable. (P = Pass, F = Fail)

Calibration Lab Data Report - Page 4 of 6

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0
 F0177R2 03/22/16

Customer: AEROCOUSTICS ENGINEERING LTD

PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	O O T	Cal Process Uncertainty	Measurement t Uncertainty	Units	TUR
DC Voltage % Source - 0-5V Ch#4										
0-5V	0%	±(0.1% Span)	-0.0050	0.0050	0.0005 V		5.8e-007	5.8e-004	V	100.0 : 1
	20%	±(0.1% Span)	0.9950	1.0050	1.0013 V		5.6e-006	5.8e-004	V	100.0 : 1
	40%	±(0.1% Span)	1.9950	2.0050	2.0004 V		1.1e-005	5.8e-004	V	100.0 : 1
	60%	±(0.1% Span)	2.9950	3.0050	3.0001 V		1.6e-005	5.8e-004	V	100.0 : 1
	80%	±(0.1% Span)	3.9950	4.0050	4.0001 V		2.1e-005	5.8e-004	V	100.0 : 1
	100%	±(0.1% Span)	4.9950	5.0050	4.9999 V		2.6e-005	5.8e-004	V	100.0 : 1

DC Voltage % Source - 0-10V Ch#1										
0-10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V		5.8e-007	1.2e-003	V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	1.999 V		1.1e-005	1.2e-003	V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.001 V		2.1e-005	1.2e-003	V	100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.000 V		3.1e-005	1.2e-003	V	100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	8.002 V		4.1e-005	1.2e-003	V	100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	10.000 V		5.2e-005	1.2e-003	V	100.0 : 1

DC Voltage % Source - 0-10V Ch#2										
0-10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V		5.8e-007	1.2e-003	V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	1.999 V		1.1e-005	1.2e-003	V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.000 V		2.1e-005	1.2e-003	V	100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.002 V		3.1e-005	1.2e-003	V	100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	8.000 V		4.1e-005	1.2e-003	V	100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	10.000 V		5.2e-005	1.2e-003	V	100.0 : 1

The column labeled Cal Process Uncertainty (CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU. Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Customer: AEROCOUSTICS ENGINEERING LTD

PO Number: 2016.06.27C

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

Description	Setpoints	Accuracy	Low Limit	High Limit	As Found / As Left	Cal		T	
						Process	Measurement		
						Uncertainty	Uncertainty	Units	TUR
DC Voltage % Source - 0-10V Ch#3									
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.002 V	5.8e-007	1.2e-003	V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	1.999 V	1.1e-005	1.2e-003	V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.001 V	2.1e-005	1.2e-003	V	100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.002 V	3.1e-005	1.2e-003	V	100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	8.001 V	4.1e-005	1.2e-003	V	100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	10.001 V	5.2e-005	1.2e-003	V	100.0 : 1

DC Voltage % Source - 0-10V Ch#4									
0 - 10V	0%	±(0.1% Span)	-0.010	0.010	0.001 V	5.8e-007	1.2e-003	V	100.0 : 1
	20%	±(0.1% Span)	1.990	2.010	2.000 V	1.1e-005	1.2e-003	V	100.0 : 1
	40%	±(0.1% Span)	3.990	4.010	4.000 V	2.1e-005	1.2e-003	V	100.0 : 1
	60%	±(0.1% Span)	5.990	6.010	6.000 V	3.1e-005	1.2e-003	V	100.0 : 1
	80%	±(0.1% Span)	7.990	8.010	8.002 V	4.1e-005	1.2e-003	V	100.0 : 1
	100%	±(0.1% Span)	9.990	10.010	10.000 V	5.2e-005	1.2e-003	V	100.0 : 1

As Found and As Left Data recorded on July 11, 2016

Temperature 75.0°F / 23.9°C Relative Humidity 39% Temp/RH Asset LEM-0005

Asset	Manufacturer	Model	Description	Cal Date	Due Date	Traceability Numbers
NT0339	HP	3458A Opt 002	Digital Multimeter, 8.5 Digit	Nov 21, 2015	Nov 30, 2016	1-7363155174-1

The column labeled Cal Process Uncertainty(CPU) does not include the short term component of the UUT. The column labeled Measurement Uncertainty includes both CPU and the short term component of the UUT. TUR is calculated using CPU. Note: Reported resolution of the UUT does not represent calibration uncertainty or accuracy of the UUT.

Revision 0

Field not applicable. (P = Pass, F = Fail)

Calibration Lab Data Report - Page 6 of 6

Certificate/SO Number: 9-Q0G8J-20-1 Revision 0

F0177R2 03/22/16

ISO 17025

As Left RECALIBRATION CERTIFICATE

Sales Region: AMERICAS
 Account: Aercoustics engineering Limited

Instrument: LMS SCADAS
 Manufacturer: Siemens Industry Software B.V.
 Type: SCR202
 Serial number(s): 22143211

Calibration method: Two calibrated external standards (DC voltage and frequency) are used to calibrate the internal LMS SCADAS references: time/frequency accuracy of the internal system clock and amplitude accuracy of the internal signal sources. All input channels are calibrated against the internal references.

Ambient conditions: The calibrations have been carried out in a controlled environment, at an ambient temperature of 22,8°C and a relative humidity of 50,2%.

Calibration date: August 17, 2016

Results: The calibration results, together with their associated uncertainties, are included in this calibration certificate.
Calibration results within specification.

Uncertainty: The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor $k=2$, which for a normal distribution corresponds to a coverage probability of approximately 95%.
 The standard uncertainty of measurement has been determined in accordance with publication EA-4/02.

Traceability: The measurements have been executed using methods for which the traceability to international standards has been demonstrated towards the Raad voor Accreditatie.

Breda, August 17, 2016

Calibration performed by:

H. Dam

Certificate approved by:

M.C.A.G. Damen

The Raad voor Accreditatie is one of the signatories of the Multilateral Agreement of the European Cooperation for Accreditation (EA) for the mutual recognition of calibration certificates.

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.

This certificate is issued provided that neither Siemens Industry Software B.V. nor the Raad voor Accreditatie assumes any liability.

Certificate number: 22143211-20160817-1

Page: 1 of 16



Table of contents

1	Explanation of the factory calibration procedure	3
2	External reference - used equipment	4
3	System configuration	5
4	V8_E_h18s0	6
4.1	Gain Accuracy after Adjustment	6
4.2	Residual Offset after Adjustment	9
4.3	Total Harmonic Distortion	11
4.4	RMS Noise	12
4.5	Spurious Free Floor	13
4.6	Inter-channel Crosstalk	14
4.7	Inter-channel Phase Match	15
5	SYSCON_REC_h11s0	16
5.1	Gain Accuracy after Adjustment	16



1 ***Explanation of the factory calibration procedure***

The production process of an LMS SCADAS front-end consists of a number of stages.

Every single board or module that will be part of the system is tested extensively on reliability and functionality before it is inserted in the LMS SCADAS frame.

After assembly, the amplitude accuracy and offset errors of all input and output channels are adjusted to a value as close to zero as possible. The adjustment procedure incorporates external measurement equipment, which is documented in the next section of this report.

As a final step, the front-end is submitted to a factory calibration. The factory calibration verifies whether all input and output channels meet their published specifications with respect to amplitude accuracy, offset, and a number of dynamic capabilities such as distortion, signal to noise ratio and inter-channel crosstalk. The measurements that are done as a part of the calibration use an internal reference source, which has been calibrated against an external standard (documented in the next section of this report).

The results of this calibration procedure are documented in the *Calibration Certificate* you have in front of you.



2 External reference - used equipment

	Type	Serial Number	Cal Certificate	Cal Date
Digital multimeter	Agilent 34401A	MY41040399	201604476.00	22-July-2016
Calibration software	2.10.0001	Na	Na	Na

The external reference (DMM) is calibrated on a yearly basis by a calibration laboratory that is ISO17025:2005 accredited by The Dutch Accreditation Council RvA.



3 System configuration

Frame	Backplane Module	Conditioner	Unique number	Hardware version	Software version	Option
Master (0)			0022143211			
	V8_E (1)		2013333008	18	0	
	V8_E (2)		2013333032	18	0	
	SYSCON_REC (3)		2013215010	11	0	
		SYSCPB (0)	2013376010	3	0	
	PS12-2 MOB (4)		2014154022	17	11	



4 V8_E_h18s0

4.1 Gain Accuracy after Adjustment

Description of calibration:

Determination of the amplitude accuracy of the input channels over all input ranges and available ADC bandwidths, by applying an accurate 1kHz -3dBFS (max 4V) sine wave which is generated by the internal reference generator. For charge amplifiers, the reference voltage signal is translated to a reference charge signal.

The reported values represent the deviations from the expected signal amplitude, both absolute (either in Volt or Coulomb, depending on the input channel type) and relative (in %).

AdcBw 102400Hz, Range 0.316V Alternating voltage 100mV < IR <= 316mV Spec: <= ±0.100% Uncertainty: 72µV	
Chan	Value
0,1,x,0	-0.124 mV, -0.055%
0,1,x,1	-0.126 mV, -0.056%
0,1,x,2	-0.128 mV, -0.057%
0,1,x,3	-0.127 mV, -0.057%
0,1,x,4	-0.127 mV, -0.057%
0,1,x,5	-0.131 mV, -0.058%
0,1,x,6	-0.125 mV, -0.056%
0,1,x,7	-0.125 mV, -0.056%
0,2,x,0	-0.127 mV, -0.057%
0,2,x,1	-0.128 mV, -0.057%
0,2,x,2	-0.125 mV, -0.056%
0,2,x,3	-0.128 mV, -0.057%
0,2,x,4	-0.126 mV, -0.057%
0,2,x,5	-0.128 mV, -0.057%
0,2,x,6	-0.127 mV, -0.057%
0,2,x,7	-0.128 mV, -0.057%

AdcBw 102400Hz, Range 1V Alternating voltage 316mV < IR <= 1V Spec: <= ±0.100% Uncertainty: 140µV	
Chan	Value
0,1,x,0	-0.311 mV, -0.044%
0,1,x,1	-0.320 mV, -0.045%
0,1,x,2	-0.318 mV, -0.045%
0,1,x,3	-0.317 mV, -0.045%
0,1,x,4	-0.311 mV, -0.044%
0,1,x,5	-0.323 mV, -0.046%
0,1,x,6	-0.312 mV, -0.044%
0,1,x,7	-0.313 mV, -0.044%
0,2,x,0	-0.322 mV, -0.046%
0,2,x,1	-0.324 mV, -0.046%
0,2,x,2	-0.318 mV, -0.045%
0,2,x,3	-0.321 mV, -0.045%
0,2,x,4	-0.316 mV, -0.045%
0,2,x,5	-0.319 mV, -0.045%
0,2,x,6	-0.320 mV, -0.045%
0,2,x,7	-0.318 mV, -0.045%

AdcBw 102400Hz, Range 3.16V Alternating voltage 1V < IR <= 3.16V Spec: <= ±0.100% Uncertainty: 370µV	
Chan	Value
0,1,x,0	-0.796 mV, -0.036%
0,1,x,1	-0.831 mV, -0.037%
0,1,x,2	-0.825 mV, -0.037%
0,1,x,3	-0.823 mV, -0.037%
0,1,x,4	-0.813 mV, -0.036%
0,1,x,5	-0.840 mV, -0.038%
0,1,x,6	-0.803 mV, -0.036%
0,1,x,7	-0.816 mV, -0.037%
0,2,x,0	-0.849 mV, -0.038%
0,2,x,1	-0.835 mV, -0.037%
0,2,x,2	-0.827 mV, -0.037%
0,2,x,3	-0.848 mV, -0.038%
0,2,x,4	-0.820 mV, -0.037%
0,2,x,5	-0.820 mV, -0.037%
0,2,x,6	-0.838 mV, -0.038%
0,2,x,7	-0.818 mV, -0.037%



AdcBw 102400Hz, Range 10V
Alternating voltage 3.16V < IR
<= 10V
Spec: <= ±0.100%
Uncertainty: 640µV

Chan	Value
0,1,x,0	-1.261 mV, -0.032%
0,1,x,1	-1.283 mV, -0.032%
0,1,x,2	-1.302 mV, -0.033%
0,1,x,3	-1.308 mV, -0.033%
0,1,x,4	-1.290 mV, -0.032%
0,1,x,5	-1.331 mV, -0.033%
0,1,x,6	-1.287 mV, -0.032%
0,1,x,7	-1.288 mV, -0.032%
0,2,x,0	-1.317 mV, -0.033%
0,2,x,1	-1.285 mV, -0.032%
0,2,x,2	-1.272 mV, -0.032%
0,2,x,3	-1.307 mV, -0.033%
0,2,x,4	-1.305 mV, -0.033%
0,2,x,5	-1.285 mV, -0.032%
0,2,x,6	-1.290 mV, -0.032%
0,2,x,7	-1.299 mV, -0.032%

AdcBw 51200Hz, Range 1V
Alternating voltage 316mV < IR
<= 1V
Spec: <= ±0.100%
Uncertainty: 140µV

Chan	Value
0,1,x,0	-0.169 mV, -0.024%
0,1,x,1	-0.178 mV, -0.025%
0,1,x,2	-0.176 mV, -0.025%
0,1,x,3	-0.175 mV, -0.025%
0,1,x,4	-0.171 mV, -0.024%
0,1,x,5	-0.182 mV, -0.026%
0,1,x,6	-0.171 mV, -0.024%
0,1,x,7	-0.172 mV, -0.024%
0,2,x,0	-0.181 mV, -0.026%
0,2,x,1	-0.180 mV, -0.026%
0,2,x,2	-0.174 mV, -0.025%
0,2,x,3	-0.178 mV, -0.025%
0,2,x,4	-0.174 mV, -0.025%
0,2,x,5	-0.176 mV, -0.025%
0,2,x,6	-0.177 mV, -0.025%
0,2,x,7	-0.176 mV, -0.025%

AdcBw 51200Hz, Range 10V
Alternating voltage 3.16V < IR
<= 10V
Spec: <= ±0.100%
Uncertainty: 640µV

Chan	Value
0,1,x,0	-0.766 mV, -0.019%
0,1,x,1	-0.787 mV, -0.020%
0,1,x,2	-0.802 mV, -0.020%
0,1,x,3	-0.808 mV, -0.020%
0,1,x,4	-0.793 mV, -0.020%
0,1,x,5	-0.829 mV, -0.021%
0,1,x,6	-0.795 mV, -0.020%
0,1,x,7	-0.794 mV, -0.020%
0,2,x,0	-0.818 mV, -0.020%
0,2,x,1	-0.786 mV, -0.020%
0,2,x,2	-0.777 mV, -0.019%
0,2,x,3	-0.810 mV, -0.020%
0,2,x,4	-0.804 mV, -0.020%
0,2,x,5	-0.787 mV, -0.020%
0,2,x,6	-0.797 mV, -0.020%
0,2,x,7	-0.803 mV, -0.020%

AdcBw 51200Hz, Range 0.316V
Alternating voltage 100mV < IR
<= 316mV
Spec: <= ±0.100%
Uncertainty: 72µV

Chan	Value
0,1,x,0	-0.060 mV, -0.027%
0,1,x,1	-0.063 mV, -0.028%
0,1,x,2	-0.065 mV, -0.029%
0,1,x,3	-0.064 mV, -0.028%
0,1,x,4	-0.063 mV, -0.028%
0,1,x,5	-0.066 mV, -0.030%
0,1,x,6	-0.062 mV, -0.028%
0,1,x,7	-0.062 mV, -0.028%
0,2,x,0	-0.064 mV, -0.029%
0,2,x,1	-0.064 mV, -0.029%
0,2,x,2	-0.062 mV, -0.028%
0,2,x,3	-0.064 mV, -0.029%
0,2,x,4	-0.063 mV, -0.028%
0,2,x,5	-0.064 mV, -0.029%
0,2,x,6	-0.064 mV, -0.029%
0,2,x,7	-0.065 mV, -0.029%

AdcBw 51200Hz, Range 3.16V
Alternating voltage 1V < IR
<= 3.16V
Spec: <= ±0.100%
Uncertainty: 370µV

Chan	Value
0,1,x,0	-0.479 mV, -0.021%
0,1,x,1	-0.512 mV, -0.023%
0,1,x,2	-0.504 mV, -0.023%
0,1,x,3	-0.504 mV, -0.023%
0,1,x,4	-0.500 mV, -0.022%
0,1,x,5	-0.524 mV, -0.023%
0,1,x,6	-0.492 mV, -0.022%
0,1,x,7	-0.503 mV, -0.023%
0,2,x,0	-0.528 mV, -0.024%
0,2,x,1	-0.511 mV, -0.023%
0,2,x,2	-0.505 mV, -0.023%
0,2,x,3	-0.526 mV, -0.024%
0,2,x,4	-0.503 mV, -0.022%
0,2,x,5	-0.502 mV, -0.022%
0,2,x,6	-0.517 mV, -0.023%
0,2,x,7	-0.503 mV, -0.022%

AdcBw 25600Hz, Range 0.316V
Alternating voltage 100mV < IR
<= 316mV
Spec: <= ±0.100%
Uncertainty: 72µV

Chan	Value
0,1,x,0	-0.040 mV, -0.018%
0,1,x,1	-0.042 mV, -0.019%
0,1,x,2	-0.043 mV, -0.019%
0,1,x,3	-0.042 mV, -0.019%
0,1,x,4	-0.042 mV, -0.019%
0,1,x,5	-0.045 mV, -0.020%
0,1,x,6	-0.041 mV, -0.018%
0,1,x,7	-0.042 mV, -0.019%
0,2,x,0	-0.043 mV, -0.019%
0,2,x,1	-0.042 mV, -0.019%
0,2,x,2	-0.041 mV, -0.018%
0,2,x,3	-0.043 mV, -0.019%
0,2,x,4	-0.042 mV, -0.019%
0,2,x,5	-0.043 mV, -0.019%
0,2,x,6	-0.042 mV, -0.019%
0,2,x,7	-0.043 mV, -0.019%



**AdcBw 25600Hz, Range 1V
Alternating voltage 316mV <
IR <= 1V
Spec: <= ±0.100%
Uncertainty: 140µV**

Chan	Value
0,1,x,0	-0.120 mV, -0.017%
0,1,x,1	-0.128 mV, -0.018%
0,1,x,2	-0.126 mV, -0.018%
0,1,x,3	-0.125 mV, -0.018%
0,1,x,4	-0.122 mV, -0.017%
0,1,x,5	-0.131 mV, -0.019%
0,1,x,6	-0.122 mV, -0.017%
0,1,x,7	-0.123 mV, -0.017%
0,2,x,0	-0.130 mV, -0.018%
0,2,x,1	-0.129 mV, -0.018%
0,2,x,2	-0.125 mV, -0.018%
0,2,x,3	-0.128 mV, -0.018%
0,2,x,4	-0.125 mV, -0.018%
0,2,x,5	-0.126 mV, -0.018%
0,2,x,6	-0.128 mV, -0.018%
0,2,x,7	-0.126 mV, -0.018%

**AdcBw 25600Hz, Range 3.16V
Alternating voltage 1V < IR <=
3.16V
Spec: <= ±0.100%
Uncertainty: 370µV**

Chan	Value
0,1,x,0	-0.328 mV, -0.015%
0,1,x,1	-0.354 mV, -0.016%
0,1,x,2	-0.350 mV, -0.016%
0,1,x,3	-0.349 mV, -0.016%
0,1,x,4	-0.347 mV, -0.016%
0,1,x,5	-0.367 mV, -0.016%
0,1,x,6	-0.341 mV, -0.015%
0,1,x,7	-0.350 mV, -0.016%
0,2,x,0	-0.370 mV, -0.017%
0,2,x,1	-0.356 mV, -0.016%
0,2,x,2	-0.350 mV, -0.016%
0,2,x,3	-0.367 mV, -0.016%
0,2,x,4	-0.349 mV, -0.016%
0,2,x,5	-0.349 mV, -0.016%
0,2,x,6	-0.361 mV, -0.016%
0,2,x,7	-0.347 mV, -0.016%

**AdcBw 25600Hz, Range 10V
Alternating voltage 3.16V < IR
<= 10V
Spec: <= ±0.100%
Uncertainty: 640µV**

Chan	Value
0,1,x,0	-0.544 mV, -0.014%
0,1,x,1	-0.561 mV, -0.014%
0,1,x,2	-0.573 mV, -0.014%
0,1,x,3	-0.576 mV, -0.014%
0,1,x,4	-0.560 mV, -0.014%
0,1,x,5	-0.589 mV, -0.015%
0,1,x,6	-0.567 mV, -0.014%
0,1,x,7	-0.567 mV, -0.014%
0,2,x,0	-0.583 mV, -0.015%
0,2,x,1	-0.558 mV, -0.014%
0,2,x,2	-0.550 mV, -0.014%
0,2,x,3	-0.575 mV, -0.014%
0,2,x,4	-0.571 mV, -0.014%
0,2,x,5	-0.559 mV, -0.014%
0,2,x,6	-0.567 mV, -0.014%
0,2,x,7	-0.573 mV, -0.014%



4.2 Residual Offset after Adjustment

Description of calibration:

Determination of the residual input offsets of the input channels over all input ranges and available ADC bandwidths, by internally shorting the input channels to ground.

AdcBw 102400Hz, Range 0.316V Direct voltage IR <= 316mV Spec: <= ±0.316 mV Uncertainty: 4.8µV	
Chan	Value
0,1,x,0	-0.002 mV
0,1,x,1	0.002 mV
0,1,x,2	0.004 mV
0,1,x,3	0.011 mV
0,1,x,4	0.009 mV
0,1,x,5	0.009 mV
0,1,x,6	0.007 mV
0,1,x,7	0.014 mV
0,2,x,0	0.010 mV
0,2,x,1	0.008 mV
0,2,x,2	0.002 mV
0,2,x,3	0.003 mV
0,2,x,4	-0.002 mV
0,2,x,5	-0.002 mV
0,2,x,6	0.001 mV
0,2,x,7	0.000 mV

AdcBw 102400Hz, Range 3.16V Direct voltage 1V < IR <= 3.16V Spec: <= ±3.160 mV Uncertainty: 8µV	
Chan	Value
0,1,x,0	0.006 mV
0,1,x,1	0.002 mV
0,1,x,2	0.021 mV
0,1,x,3	0.009 mV
0,1,x,4	0.013 mV
0,1,x,5	0.014 mV
0,1,x,6	0.016 mV
0,1,x,7	0.007 mV
0,2,x,0	0.017 mV
0,2,x,1	0.020 mV
0,2,x,2	0.007 mV
0,2,x,3	0.007 mV
0,2,x,4	0.010 mV
0,2,x,5	0.002 mV
0,2,x,6	0.001 mV
0,2,x,7	0.023 mV

AdcBw 51200Hz, Range 0.316V Direct voltage IR <= 316mV Spec: <= ±0.316 mV Uncertainty: 4.8µV	
Chan	Value
0,1,x,0	-0.001 mV
0,1,x,1	-0.003 mV
0,1,x,2	0.003 mV
0,1,x,3	0.007 mV
0,1,x,4	0.002 mV
0,1,x,5	0.002 mV
0,1,x,6	0.002 mV
0,1,x,7	0.001 mV
0,2,x,0	0.005 mV
0,2,x,1	0.005 mV
0,2,x,2	0.001 mV
0,2,x,3	0.001 mV
0,2,x,4	-0.001 mV
0,2,x,5	-0.004 mV
0,2,x,6	0.001 mV
0,2,x,7	0.000 mV

AdcBw 51200Hz, Range 3.16V Direct voltage 1V < IR <= 3.16V Spec: <= ±3.160 mV Uncertainty: 8µV	
Chan	Value
0,1,x,0	0.006 mV
0,1,x,1	0.002 mV
0,1,x,2	0.024 mV
0,1,x,3	0.016 mV
0,1,x,4	0.014 mV
0,1,x,5	0.005 mV
0,1,x,6	0.017 mV
0,1,x,7	0.005 mV
0,2,x,0	0.008 mV
0,2,x,1	0.011 mV
0,2,x,2	0.009 mV
0,2,x,3	0.011 mV
0,2,x,4	0.013 mV
0,2,x,5	-0.002 mV
0,2,x,6	0.013 mV
0,2,x,7	0.014 mV

AdcBw 102400Hz, Range 1V Direct voltage 316mV < IR <= 1V Spec: <= ±1.000 mV Uncertainty: 5.2µV	
Chan	Value
0,1,x,0	0.003 mV
0,1,x,1	-0.000 mV
0,1,x,2	0.005 mV
0,1,x,3	0.010 mV
0,1,x,4	0.007 mV
0,1,x,5	0.008 mV
0,1,x,6	0.006 mV
0,1,x,7	0.011 mV
0,2,x,0	0.009 mV
0,2,x,1	0.007 mV
0,2,x,2	0.003 mV
0,2,x,3	0.004 mV
0,2,x,4	0.003 mV
0,2,x,5	-0.000 mV
0,2,x,6	0.002 mV
0,2,x,7	0.004 mV

AdcBw 102400Hz, Range 10V Direct voltage 3.16V < IR <= 10V Spec: <= ±10.000 mV Uncertainty: 21µV	
Chan	Value
0,1,x,0	0.024 mV
0,1,x,1	0.025 mV
0,1,x,2	0.057 mV
0,1,x,3	0.035 mV
0,1,x,4	0.033 mV
0,1,x,5	0.008 mV
0,1,x,6	0.044 mV
0,1,x,7	0.017 mV
0,2,x,0	0.036 mV
0,2,x,1	0.044 mV
0,2,x,2	0.020 mV
0,2,x,3	0.012 mV
0,2,x,4	0.024 mV
0,2,x,5	0.024 mV
0,2,x,6	0.024 mV
0,2,x,7	0.050 mV

AdcBw 51200Hz, Range 1V Direct voltage 316mV < IR <= 1V Spec: <= ±1.000 mV Uncertainty: 5.2µV	
Chan	Value
0,1,x,0	0.003 mV
0,1,x,1	-0.003 mV
0,1,x,2	0.007 mV
0,1,x,3	0.007 mV
0,1,x,4	0.005 mV
0,1,x,5	0.002 mV
0,1,x,6	0.004 mV
0,1,x,7	0.001 mV
0,2,x,0	0.007 mV
0,2,x,1	0.005 mV
0,2,x,2	0.003 mV
0,2,x,3	0.005 mV
0,2,x,4	0.002 mV
0,2,x,5	-0.003 mV
0,2,x,6	0.002 mV
0,2,x,7	0.003 mV

AdcBw 51200Hz, Range 10V Direct voltage 3.16V < IR <= 10V Spec: <= ±10.000 mV Uncertainty: 21µV	
Chan	Value
0,1,x,0	0.022 mV
0,1,x,1	0.023 mV
0,1,x,2	0.054 mV
0,1,x,3	0.046 mV
0,1,x,4	0.013 mV
0,1,x,5	0.029 mV
0,1,x,6	0.036 mV
0,1,x,7	0.020 mV
0,2,x,0	0.032 mV
0,2,x,1	0.054 mV
0,2,x,2	0.033 mV
0,2,x,3	0.020 mV
0,2,x,4	0.040 mV
0,2,x,5	-0.017 mV
0,2,x,6	0.037 mV
0,2,x,7	0.039 mV



**AdcBw 25600Hz,
Range 0.316V
Direct voltage IR <= 316mV
Spec: <= ±0.316 mV
Uncertainty: 4.8µV**

Chan	Value
0,1,x,0	0.003 mV
0,1,x,1	-0.003 mV
0,1,x,2	0.004 mV
0,1,x,3	0.003 mV
0,1,x,4	0.001 mV
0,1,x,5	0.004 mV
0,1,x,6	-0.002 mV
0,1,x,7	0.002 mV
0,2,x,0	0.004 mV
0,2,x,1	0.002 mV
0,2,x,2	-0.001 mV
0,2,x,3	0.002 mV
0,2,x,4	-0.001 mV
0,2,x,5	-0.005 mV
0,2,x,6	0.004 mV
0,2,x,7	-0.002 mV

**AdcBw 25600Hz,
Range 3.16V
Direct voltage 1V < IR <= 3.16V
Spec: <= ±3.160 mV
Uncertainty: 8µV**

Chan	Value
0,1,x,0	0.008 mV
0,1,x,1	-0.005 mV
0,1,x,2	0.021 mV
0,1,x,3	0.014 mV
0,1,x,4	0.008 mV
0,1,x,5	0.009 mV
0,1,x,6	0.013 mV
0,1,x,7	0.010 mV
0,2,x,0	0.014 mV
0,2,x,1	0.010 mV
0,2,x,2	0.009 mV
0,2,x,3	0.009 mV
0,2,x,4	0.012 mV
0,2,x,5	-0.006 mV
0,2,x,6	0.013 mV
0,2,x,7	0.012 mV

**AdcBw 25600Hz,
Range 1V
Direct voltage 316mV < IR <= 1V
Spec: <= ±1.000 mV
Uncertainty: 5.2µV**

Chan	Value
0,1,x,0	0.005 mV
0,1,x,1	-0.004 mV
0,1,x,2	0.005 mV
0,1,x,3	0.006 mV
0,1,x,4	0.005 mV
0,1,x,5	0.004 mV
0,1,x,6	0.002 mV
0,1,x,7	0.003 mV
0,2,x,0	0.007 mV
0,2,x,1	0.002 mV
0,2,x,2	0.002 mV
0,2,x,3	0.007 mV
0,2,x,4	0.001 mV
0,2,x,5	-0.001 mV
0,2,x,6	0.004 mV
0,2,x,7	0.003 mV

**AdcBw 25600Hz,
Range 10V
Direct voltage 3.16V < IR <= 10V
Spec: <= ±10.000 mV
Uncertainty: 21µV**

Chan	Value
0,1,x,0	0.021 mV
0,1,x,1	-0.005 mV
0,1,x,2	0.053 mV
0,1,x,3	0.038 mV
0,1,x,4	0.046 mV
0,1,x,5	0.034 mV
0,1,x,6	0.043 mV
0,1,x,7	0.012 mV
0,2,x,0	0.050 mV
0,2,x,1	0.017 mV
0,2,x,2	0.029 mV
0,2,x,3	0.023 mV
0,2,x,4	0.047 mV
0,2,x,5	0.010 mV
0,2,x,6	0.029 mV
0,2,x,7	0.036 mV



4.3 Total Harmonic Distortion

Description of calibration:

Determination of the harmonic distortion of the input channels over all input ranges, by applying an accurate 1kHz -3dBFS (max 4V) sine wave which is generated by the internal reference generator. For charge amplifiers, the reference voltage signal is translated to a reference charge signal. Harmonic components 2, 3, 4 and 5 are determined to calculate the harmonic content (either in Volt or Coulomb, depending on the input channel type) and the ratio between the fundamental tone and its harmonics (in dB).

Range 10V Distortion 3.16V < IR <= 10V Spec: <= -94.0dB Uncertainty: 2.6µV	
Chan	Value
0,1,x,0	13.957 µV, -109.1dB
0,1,x,1	14.186 µV, -109.0dB
0,1,x,2	13.857 µV, -109.2dB
0,1,x,3	14.156 µV, -109.0dB
0,1,x,4	14.211 µV, -109.0dB
0,1,x,5	13.944 µV, -109.2dB
0,1,x,6	14.361 µV, -108.9dB
0,1,x,7	14.856 µV, -108.6dB
0,2,x,0	14.242 µV, -109.0dB
0,2,x,1	14.357 µV, -108.9dB
0,2,x,2	13.956 µV, -109.1dB
0,2,x,3	14.460 µV, -108.8dB
0,2,x,4	14.146 µV, -109.0dB
0,2,x,5	14.835 µV, -108.6dB
0,2,x,6	13.401 µV, -109.5dB
0,2,x,7	15.577 µV, -108.2dB

Range 1 V Distortion 316mV < IR <= 1V Spec: <= -94.0dB Uncertainty: 290nV	
Chan	Value
0,1,x,0	3.486 µV, -106.1dB
0,1,x,1	3.403 µV, -106.4dB
0,1,x,2	3.676 µV, -105.7dB
0,1,x,3	3.348 µV, -106.5dB
0,1,x,4	3.489 µV, -106.1dB
0,1,x,5	3.314 µV, -106.6dB
0,1,x,6	3.826 µV, -105.3dB
0,1,x,7	3.525 µV, -106.0dB
0,2,x,0	3.305 µV, -106.6dB
0,2,x,1	3.392 µV, -106.4dB
0,2,x,2	2.942 µV, -107.6dB
0,2,x,3	3.093 µV, -107.2dB
0,2,x,4	3.520 µV, -106.1dB
0,2,x,5	3.712 µV, -105.6dB
0,2,x,6	3.693 µV, -105.6dB
0,2,x,7	3.616 µV, -105.8dB

Range 3.16V Distortion 1V < IR <= 3.16V Spec: <= -94.0dB Uncertainty: 0.8µV	
Chan	Value
0,1,x,0	7.051 µV, -110.0dB
0,1,x,1	7.029 µV, -110.0dB
0,1,x,2	6.916 µV, -110.2dB
0,1,x,3	6.992 µV, -110.1dB
0,1,x,4	7.025 µV, -110.1dB
0,1,x,5	7.099 µV, -110.0dB
0,1,x,6	7.951 µV, -109.0dB
0,1,x,7	8.450 µV, -108.4dB
0,2,x,0	7.248 µV, -109.8dB
0,2,x,1	8.000 µV, -108.9dB
0,2,x,2	6.448 µV, -110.8dB
0,2,x,3	6.918 µV, -110.2dB
0,2,x,4	7.573 µV, -109.4dB
0,2,x,5	8.423 µV, -108.5dB
0,2,x,6	6.587 µV, -110.6dB
0,2,x,7	9.166 µV, -107.7dB

Range 0.316V Distortion 100mV < IR <= 316mV Spec: <= -91.0dB Uncertainty: 140nV	
Chan	Value
0,1,x,0	3.069 µV, -97.2dB
0,1,x,1	3.126 µV, -97.1dB
0,1,x,2	3.278 µV, -96.7dB
0,1,x,3	3.146 µV, -97.0dB
0,1,x,4	3.132 µV, -97.1dB
0,1,x,5	3.132 µV, -97.1dB
0,1,x,6	3.390 µV, -96.4dB
0,1,x,7	3.171 µV, -97.0dB
0,2,x,0	3.046 µV, -97.3dB
0,2,x,1	3.291 µV, -96.6dB
0,2,x,2	2.925 µV, -97.7dB
0,2,x,3	3.050 µV, -97.3dB
0,2,x,4	3.217 µV, -96.8dB
0,2,x,5	3.498 µV, -96.1dB
0,2,x,6	3.566 µV, -95.9dB
0,2,x,7	3.258 µV, -96.7dB



4.4 RMS Noise

Description of calibration:

Determination of the noise contribution of the input channels, by internally shorting the input channels to ground. The reported values are RMS values over the corresponding bandwidth.

Range 10V, Bw 80kHz Not in Scope Spec: < 311.0000µVrms	
Chan	Value
0,1,x,0	219.0446µVrms
0,1,x,1	215.5567µVrms
0,1,x,2	214.0229µVrms
0,1,x,3	211.9270µVrms
0,1,x,4	214.3002µVrms
0,1,x,5	214.2469µVrms
0,1,x,6	215.3279µVrms
0,1,x,7	211.1399µVrms
0,2,x,0	216.1295µVrms
0,2,x,1	229.9419µVrms
0,2,x,2	237.2607µVrms
0,2,x,3	217.7047µVrms
0,2,x,4	213.7526µVrms
0,2,x,5	215.1412µVrms
0,2,x,6	223.5220µVrms
0,2,x,7	214.6153µVrms

Range 10V, Bw 40kHz Not in Scope Spec: < 42.0000µVrms	
Chan	Value
0,1,x,0	30.4720µVrms
0,1,x,1	29.9859µVrms
0,1,x,2	29.7392µVrms
0,1,x,3	29.6890µVrms
0,1,x,4	30.1631µVrms
0,1,x,5	29.8736µVrms
0,1,x,6	30.0771µVrms
0,1,x,7	29.8148µVrms
0,2,x,0	29.7523µVrms
0,2,x,1	32.9458µVrms
0,2,x,2	33.7534µVrms
0,2,x,3	30.9976µVrms
0,2,x,4	30.1570µVrms
0,2,x,5	30.5237µVrms
0,2,x,6	31.6733µVrms
0,2,x,7	30.4409µVrms

Range 10V, Bw 20kHz Noise 3.16V < IR <= 10V Spec: <= 29.000 µV Uncertainty: 3.4nV	
Chan	Value
0,1,x,0	20.547 µV
0,1,x,1	20.520 µV
0,1,x,2	20.342 µV
0,1,x,3	19.928 µV
0,1,x,4	20.965 µV
0,1,x,5	20.080 µV
0,1,x,6	20.444 µV
0,1,x,7	20.056 µV
0,2,x,0	20.199 µV
0,2,x,1	20.513 µV
0,2,x,2	20.464 µV
0,2,x,3	20.991 µV
0,2,x,4	20.520 µV
0,2,x,5	20.915 µV
0,2,x,6	20.524 µV
0,2,x,7	20.505 µV

Range 0.316V, Bw 80kHz Not in Scope Spec: < 10.5000µVrms	
Chan	Value
0,1,x,0	7.3205µVrms
0,1,x,1	7.3448µVrms
0,1,x,2	7.1902µVrms
0,1,x,3	7.1770µVrms
0,1,x,4	7.1586µVrms
0,1,x,5	7.2702µVrms
0,1,x,6	7.2457µVrms
0,1,x,7	7.0986µVrms
0,2,x,0	7.3025µVrms
0,2,x,1	7.7135µVrms
0,2,x,2	7.7701µVrms
0,2,x,3	7.2762µVrms
0,2,x,4	7.1374µVrms
0,2,x,5	7.2662µVrms
0,2,x,6	7.5538µVrms
0,2,x,7	7.2434µVrms

Range 0.316V, Bw 40kHz Not in Scope Spec: < 2.8000µVrms	
Chan	Value
0,1,x,0	2.1055µVrms
0,1,x,1	2.0961µVrms
0,1,x,2	2.0925µVrms
0,1,x,3	2.0993µVrms
0,1,x,4	2.0962µVrms
0,1,x,5	2.1039µVrms
0,1,x,6	2.1076µVrms
0,1,x,7	2.1053µVrms
0,2,x,0	2.0782µVrms
0,2,x,1	2.1181µVrms
0,2,x,2	2.1473µVrms
0,2,x,3	2.0894µVrms
0,2,x,4	2.0762µVrms
0,2,x,5	2.0870µVrms
0,2,x,6	2.1065µVrms
0,2,x,7	2.0784µVrms

Range 0.316V, Bw 20kHz Noise IR <= 316mV Spec: <= 1.980 µV Uncertainty: 2.0nV	
Chan	Value
0,1,x,0	1.491 µV
0,1,x,1	1.489 µV
0,1,x,2	1.477 µV
0,1,x,3	1.483 µV
0,1,x,4	1.478 µV
0,1,x,5	1.487 µV
0,1,x,6	1.491 µV
0,1,x,7	1.482 µV
0,2,x,0	1.463 µV
0,2,x,1	1.472 µV
0,2,x,2	1.505 µV
0,2,x,3	1.475 µV
0,2,x,4	1.489 µV
0,2,x,5	1.480 µV
0,2,x,6	1.475 µV
0,2,x,7	1.465 µV



4.5 Spurious Free Floor

Description of calibration:

Determination of the peak spurious components generated by the input channels, by internally shorting the input channels to ground. The reported values are peak values over the corresponding bandwidth.

Range 10V, Bw 80kHz Not in Scope Spec: < 40.0000µV	
Chan	Value
0,1,x,0	19.2538µV
0,1,x,1	18.7518µV
0,1,x,2	22.2457µV
0,1,x,3	21.8555µV
0,1,x,4	19.2275µV
0,1,x,5	21.6950µV
0,1,x,6	19.8464µV
0,1,x,7	21.3278µV
0,2,x,0	23.2187µV
0,2,x,1	19.2456µV
0,2,x,2	24.0384µV
0,2,x,3	22.7264µV
0,2,x,4	18.8870µV
0,2,x,5	17.6961µV
0,2,x,6	24.2841µV
0,2,x,7	23.4342µV

Range 10V, Bw 40kHz Not in Scope Spec: < 3.0000µV	
Chan	Value
0,1,x,0	1.8185µV
0,1,x,1	2.1372µV
0,1,x,2	1.8303µV
0,1,x,3	1.5170µV
0,1,x,4	1.7215µV
0,1,x,5	1.4665µV
0,1,x,6	1.7835µV
0,1,x,7	1.9818µV
0,2,x,0	1.5034µV
0,2,x,1	2.1010µV
0,2,x,2	2.1691µV
0,2,x,3	1.9195µV
0,2,x,4	2.3745µV
0,2,x,5	2.0012µV
0,2,x,6	1.9528µV
0,2,x,7	2.4614µV

Range 10V, Bw 20kHz Spurious 3.16V < IR <= 10V Spec: <= 2.300 µV Uncertainty: 3.4nV	
Chan	Value
0,1,x,0	1.435 µV
0,1,x,1	1.487 µV
0,1,x,2	1.256 µV
0,1,x,3	1.365 µV
0,1,x,4	1.251 µV
0,1,x,5	1.140 µV
0,1,x,6	1.261 µV
0,1,x,7	1.195 µV
0,2,x,0	1.217 µV
0,2,x,1	1.296 µV
0,2,x,2	1.364 µV
0,2,x,3	1.812 µV
0,2,x,4	0.974 µV
0,2,x,5	2.232 µV
0,2,x,6	1.387 µV
0,2,x,7	1.402 µV

ICP Not in Scope Spec: < 0.2600µVp	
Chan	Value
0,1,x,0	0.0767µVp
0,1,x,1	0.0727µVp
0,1,x,2	0.0826µVp
0,1,x,3	0.0991µVp
0,1,x,4	0.0860µVp
0,1,x,5	0.0793µVp
0,1,x,6	0.0993µVp
0,1,x,7	0.0853µVp
0,2,x,0	0.0950µVp
0,2,x,1	0.0848µVp
0,2,x,2	0.0896µVp
0,2,x,3	0.0841µVp
0,2,x,4	0.0791µVp
0,2,x,5	0.0866µVp
0,2,x,6	0.0804µVp
0,2,x,7	0.0679µVp

Range 0.316V, Bw 80kHz Not in Scope Spec: < 1.2000µV	
Chan	Value
0,1,x,0	0.7142µV
0,1,x,1	0.6543µV
0,1,x,2	0.5939µV
0,1,x,3	0.5608µV
0,1,x,4	0.6519µV
0,1,x,5	0.5498µV
0,1,x,6	0.5648µV
0,1,x,7	0.6774µV
0,2,x,0	0.6248µV
0,2,x,1	0.6736µV
0,2,x,2	0.7115µV
0,2,x,3	0.8499µV
0,2,x,4	0.6765µV
0,2,x,5	0.6215µV
0,2,x,6	0.6478µV
0,2,x,7	0.6009µV

Range 0.316V, Bw 40kHz Not in Scope Spec: < 0.1600µV	
Chan	Value
0,1,x,0	0.0839µV
0,1,x,1	0.0835µV
0,1,x,2	0.0898µV
0,1,x,3	0.0987µV
0,1,x,4	0.0982µV
0,1,x,5	0.1038µV
0,1,x,6	0.0782µV
0,1,x,7	0.1087µV
0,2,x,0	0.0873µV
0,2,x,1	0.0876µV
0,2,x,2	0.1089µV
0,2,x,3	0.0865µV
0,2,x,4	0.0995µV
0,2,x,5	0.0865µV
0,2,x,6	0.0864µV
0,2,x,7	0.0806µV

Range 0.316V, Bw 20kHz Spurious IR <= 316mV Spec: <= 0.130 µV Uncertainty: 2.0nV	
Chan	Value
0,1,x,0	0.077 µV
0,1,x,1	0.071 µV
0,1,x,2	0.064 µV
0,1,x,3	0.064 µV
0,1,x,4	0.059 µV
0,1,x,5	0.070 µV
0,1,x,6	0.067 µV
0,1,x,7	0.077 µV
0,2,x,0	0.075 µV
0,2,x,1	0.084 µV
0,2,x,2	0.083 µV
0,2,x,3	0.067 µV
0,2,x,4	0.060 µV
0,2,x,5	0.071 µV
0,2,x,6	0.063 µV
0,2,x,7	0.061 µV



4.6 Inter-channel Crosstalk

Description of calibration:

Determination of the crosstalk between the input channels in a system. The channel under calibration is internally shorted to ground, while its neighbour channels are fed with a near full scale sine wave signal which is generated by the internal reference generator. This is done for two input range settings of the channel under calibration, and two signal frequencies. The reported results represent the measured crosstalk values in the channels under calibration (either in Volt or Coulomb, depending on the input channel type) and the ratio between the applied signal amplitude and the crosstalk values (in dB).

Range 0.316V, F 1K5 Crosstalk 100mV < IR <= 316mV Spec: <= -120.0dB Uncertainty: 68nV	
Chan	Value
0,1,x,0	0.124 µV, -132.1dB
0,1,x,1	0.120 µV, -132.4dB
0,1,x,2	0.124 µV, -132.1dB
0,1,x,3	0.106 µV, -133.5dB
0,1,x,4	0.092 µV, -134.7dB
0,1,x,5	0.071 µV, -136.9dB
0,1,x,6	0.103 µV, -133.7dB
0,1,x,7	0.102 µV, -133.8dB
0,2,x,0	0.128 µV, -131.9dB
0,2,x,1	0.116 µV, -132.7dB
0,2,x,2	0.133 µV, -131.5dB
0,2,x,3	0.102 µV, -133.8dB
0,2,x,4	0.096 µV, -134.3dB
0,2,x,5	0.090 µV, -134.9dB
0,2,x,6	0.130 µV, -131.7dB
0,2,x,7	0.137 µV, -131.2dB

Range 0.316V, F 15K Crosstalk 100mV < IR <= 316mV Spec: <= -107.0dB Uncertainty: 68nV	
Chan	Value
0,1,x,0	0.815 µV, -115.8dB
0,1,x,1	1.362 µV, -111.3dB
0,1,x,2	1.374 µV, -111.2dB
0,1,x,3	1.381 µV, -111.2dB
0,1,x,4	1.381 µV, -111.2dB
0,1,x,5	1.349 µV, -111.4dB
0,1,x,6	1.181 µV, -112.5dB
0,1,x,7	1.116 µV, -113.0dB
0,2,x,0	0.818 µV, -115.7dB
0,2,x,1	1.330 µV, -111.5dB
0,2,x,2	1.387 µV, -111.1dB
0,2,x,3	1.377 µV, -111.2dB
0,2,x,4	1.373 µV, -111.2dB
0,2,x,5	1.340 µV, -111.4dB
0,2,x,6	1.240 µV, -112.1dB
0,2,x,7	1.084 µV, -113.3dB

Range 10V, F 1K5 Crosstalk 3.16V < IR <= 10V Spec: <= -108.0dB Uncertainty: 1.3µV	
Chan	Value
0,1,x,0	0.310 µV, -124.2dB
0,1,x,1	0.528 µV, -119.5dB
0,1,x,2	0.361 µV, -122.8dB
0,1,x,3	0.460 µV, -120.7dB
0,1,x,4	0.249 µV, -126.0dB
0,1,x,5	0.469 µV, -120.6dB
0,1,x,6	0.347 µV, -123.2dB
0,1,x,7	0.402 µV, -121.9dB
0,2,x,0	0.247 µV, -126.1dB
0,2,x,1	0.337 µV, -123.4dB
0,2,x,2	0.180 µV, -128.9dB
0,2,x,3	0.478 µV, -120.4dB
0,2,x,4	0.258 µV, -125.8dB
0,2,x,5	0.467 µV, -120.6dB
0,2,x,6	0.504 µV, -119.9dB
0,2,x,7	0.128 µV, -131.8dB

Range 10V, F 15K Crosstalk 3.16V < IR <= 10V Spec: <= -105.0dB Uncertainty: 1.3µV	
Chan	Value
0,1,x,0	0.911 µV, -114.8dB
0,1,x,1	1.402 µV, -111.0dB
0,1,x,2	1.593 µV, -109.9dB
0,1,x,3	1.599 µV, -109.9dB
0,1,x,4	1.723 µV, -109.3dB
0,1,x,5	1.399 µV, -111.1dB
0,1,x,6	1.602 µV, -109.9dB
0,1,x,7	1.082 µV, -113.3dB
0,2,x,0	0.910 µV, -114.8dB
0,2,x,1	1.560 µV, -110.1dB
0,2,x,2	1.548 µV, -110.2dB
0,2,x,3	1.506 µV, -110.4dB
0,2,x,4	1.460 µV, -110.7dB
0,2,x,5	1.464 µV, -110.7dB
0,2,x,6	1.752 µV, -109.1dB
0,2,x,7	1.130 µV, -112.9dB



4.7 Inter-channel Phase Match

Description of calibration:

Determination of the phase difference between the input channels in a system, by applying an accurate -3dBFS (max 4V) sine wave which is generated by the internal reference generator. For charge amplifiers, the reference voltage signal is translated to a reference charge signal. The reported values represent the highest phase differences found between any of the channels in the system. This is done for two input range settings and two signal frequencies.

Range 10V, F 9k9 Not in Scope Spec: < 0.3000°	
Chan	Value
0,1,x,0	0.0169°
0,1,x,1	0.0308°
0,1,x,2	0.0242°
0,1,x,3	0.0170°
0,1,x,4	0.0237°
0,1,x,5	0.0230°
0,1,x,6	0.0156°
0,1,x,7	0.0291°
0,2,x,0	0.0308°
0,2,x,1	0.0191°
0,2,x,2	0.0210°
0,2,x,3	0.0175°
0,2,x,4	0.0158°
0,2,x,5	0.0219°
0,2,x,6	0.0200°
0,2,x,7	0.0279°

Range 10V, F 19k9 Not in Scope Spec: < 0.4000°	
Chan	Value
0,1,x,0	0.0333°
0,1,x,1	0.0612°
0,1,x,2	0.0483°
0,1,x,3	0.0333°
0,1,x,4	0.0471°
0,1,x,5	0.0461°
0,1,x,6	0.0306°
0,1,x,7	0.0593°
0,2,x,0	0.0612°
0,2,x,1	0.0389°
0,2,x,2	0.0424°
0,2,x,3	0.0358°
0,2,x,4	0.0318°
0,2,x,5	0.0437°
0,2,x,6	0.0398°
0,2,x,7	0.0554°

Range 0.316V, F 9k9 Not in Scope Spec: < 0.3000°	
Chan	Value
0,1,x,0	0.0473°
0,1,x,1	0.0646°
0,1,x,2	0.0699°
0,1,x,3	0.0613°
0,1,x,4	0.0665°
0,1,x,5	0.0544°
0,1,x,6	0.0494°
0,1,x,7	0.0454°
0,2,x,0	0.0563°
0,2,x,1	0.0689°
0,2,x,2	0.0515°
0,2,x,3	0.0642°
0,2,x,4	0.0859°
0,2,x,5	0.0732°
0,2,x,6	0.0859°
0,2,x,7	0.0594°

Range 0.316V, F 19k9 Not in Scope Spec: < 0.6000°	
Chan	Value
0,1,x,0	0.0923°
0,1,x,1	0.1270°
0,1,x,2	0.1372°
0,1,x,3	0.1198°
0,1,x,4	0.1303°
0,1,x,5	0.1121°
0,1,x,6	0.1013°
0,1,x,7	0.0870°
0,2,x,0	0.1124°
0,2,x,1	0.1369°
0,2,x,2	0.1028°
0,2,x,3	0.1296°
0,2,x,4	0.1720°
0,2,x,5	0.1464°
0,2,x,6	0.1720°
0,2,x,7	0.1199°



5 SYSCON_REC_h11s0

5.1 Gain Accuracy after Adjustment

Description of calibration:

Determination of the amplitude accuracy of the input channels over all input ranges and available ADC bandwidths, by applying an accurate 1kHz -3dBFS (max 4V) sine wave which is generated by the internal reference generator. For charge amplifiers, the reference voltage signal is translated to a reference charge signal.

The reported values represent the deviations from the expected signal amplitude, both absolute (either in Volt or Coulomb, depending on the input channel type) and relative (in %).

BW 25k6	
Alternating voltage 3.16V < IR <= 10V	
Spec: <= ±0.100%	
Uncertainty: 640µV	
Chan	Value
0,x,x,0	0.239 mV, 0.006%
0,x,x,1	0.420 mV, 0.011%

BW 51k2	
Alternating voltage 3.16V < IR <= 10V	
Spec: <= ±0.100%	
Uncertainty: 640µV	
Chan	Value
0,x,x,0	0.398 mV, 0.010%
0,x,x,1	0.529 mV, 0.013%

BW 102k4	
Not in Scope	
Spec: 1.00000 ±0.10%	
Chan	Value
0,x,x,0	1.00008, 0.01%
0,x,x,1	1.00012, 0.01%

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

ACOUSTICAL CALIBRATOR

Manufactured by: BRUEL & KJAER
Model No: 4231
Serial No: 2513182
Calibration Recall No: 27880

Submitted By:

Customer:
Company: Aercoustics Engineering LTD
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. 4231 BRUE

Upon receipt for Calibration, the instrument was found to be:

Within (X)

tolerance of the indicated specification. See attached Report of Calibration.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by: 

Calibration Date: 25-Jul-17

Felix Christopher (QA Mgr.)

Certificate No: 27880 - 2

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

ISO/IEC 17025:2005

West Caldwell Calibration Laboratories, Inc.
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



REPORT OF CALIBRATION

for

Brüel & Kjær Acoustical Calibrator
Company: Aercoustics Engineering LTD

Model No.: 4231

Serial No.: 2513182
ID No.: XXXX

Calibration results:

Before data: After data:
 Before & after data same: ...X...
 Sound Pressure Level at 1000.0 Hz and pressure of 1013 hPa (mbar)
 was 113.99 dB re 20µPa

(Calibrator tested with ½" adaptor UC 0210)

IEC 1094-4 Type WS 2 P Microphone was used for measurement.

	114dB	94dB
Sound Pressure Level:	Pass	Pass
Frequency:	Pass	Pass
Distortion:	Pass	Pass
Stability:	Pass	Pass
All tested parameters:	Pass	Pass

Laboratory Environment:

Ambient Temperature:	22.6	°C
Ambient Humidity:	54.8	% RH
Ambient Pressure:	99.611	kPa
Calibration Date:	25-Jul-2017	
Calibration Due:	25-Jul-2019	
Report Number:	27880 -2	
Control Number:	27880	

The above listed instrument meets or exceeds the tested manufacturer's specifications



The IEC 942:1988 Class 1 specifications, passed.

The ANSI S1.4-1984 specifications, passed.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.09dB at 95% confidence level with a coverage factor of k=2.

Graph represents six samples of Sound Pressure Level measured at 5sec. interval.



The above listed instrument was checked using calibration procedure documented in West Caldwell

Calibration Laboratories Inc. procedure :

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NCSL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Cal. Date: 25-Jul-2017

Measurements performed by: *James Zhu*

Calibrated on WCCL system type 9700

James Zhu

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564

Tel. (585) 586-3900 FAX (585) 586-4327

*Calibration Data Record*Brüel & Kjær Acoustical Calibrator
Company: Aercoustics Engineering LTDfor
Model No.: 4231

Serial No.: 2513182

All tested parameters: Pass

Measured Sound Pressure Level (Six samples measured at 5 sec. interval)

Sample	1	113.99 dB re 20µPa	93.97 dB re 20µPa	
	2	113.99	93.97	
	3	113.99	93.98	
	4	113.99	93.97	
	5	113.99	93.97	
	6	113.99	93.96	
	Average	113.99 Spec. 114dB ± 0.2dB	93.97	Spec. 94dB ± 0.2dB

Frequency measured (Three samples at 30 sec. Interval)

Sample	1	999.98 Hz	1000.00 Hz	
	2	999.98	999.96	
	3	999.98	999.95	
	Average	999.98	999.97	Spec. 1000Hz ±0.1%

The Frequency expanded uncertainty of calibration:45µHz/Hz at 95% confidence level with a coverage factor of k=2.

Distortion measured	-49.9 dB	-46.6 dB	Spec. ≤-40dB
---------------------	----------	----------	--------------

Instruments used for calibration:	Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær 4231 S/N 2205492	1-Nov-2016	683/284413-14	1-Nov-2017
Brüel & Kjær 4134 S/N 173494	1-Nov-2016	683/284413-14	1-Nov-2017
Brüel & Kjær 2669 S/N 1835080	1-Nov-2016	683/284413-14	1-Nov-2017
HP 34401A S/N MY440029	1-Nov-2016	,287708	1-Nov-2017
Brüel & Kjær 2636 S/N 1487493	1-Nov-2016	683/284413-14	1-Nov-2017
HP 33120A S/N SG400116	1-Nov-2016	,287708	1-Nov-2017

Cal. Date: 25-Jul-2017

Tested by: James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 4231B&K

West Caldwell Calibration Laboratories Inc.

Certificate of Calibration

for

MICROPHONE UNIT

Manufactured by: **BRUEL & KJAER**
Model No: **4189-A-021**
Serial No: **2622170**
Calibration Recall No: **28047**

Submitted By:

Customer:
Company: **Aercoustics Engineering LTD**
Address:

The subject instrument was calibrated to the indicated specification using standards traceable to the National Institute of Standards and Technology or to accepted values of natural physical constants. This document certifies that the instrument met the following specification upon its return to the submitter.

West Caldwell Calibration Laboratories Procedure No. **4189-A-021 BRUE**

Upon receipt for Calibration, the instrument was found to be:

Within (X)

tolerance of the indicated specification. See attached Report of Calibration.

West Caldwell Calibration Laboratories' calibration control system meets the requirements, ISO 10012-1 MIL-STD-45662A, ANSI/NCSL Z540-1, IEC Guide 25, ISO 9001:2008 and ISO 17025.

Note: With this Certificate, Report of Calibration is included.

Approved by:

FC

Calibration Date: **20-Sep-17**

Felix Christopher (QA Mgr.)

Certificate No: **28047 - 1**

QA Doc. #1051 Rev. 2.0 10/1/01

Certificate Page 1 of 1

ISO/IEC 17025:2005

**West Caldwell
Calibration
Laboratories, Inc.**
uncompromised calibration
1575 State Route 96, Victor, NY 14564, U.S.A.



Calibration Lab. Cert. # 1533.01

West Caldwell Calibration Laboratories, Inc.
 uncompromised calibration
 1575 State Route 96, Victor NY 14564



REPORT OF CALIBRATION

for

Brüel & Kjær Microphone Unit

Model No.: 4189-A-021

Serial No.: 2622170

Mic. Model No.: 4189

Serial No.: 2625197

Preamp. Model No.: 2671

Serial No.: 2614901

Company: Aercoustics Engineering LTD

I. D. No.: XXXX

Calibration results:

Before & after data same: ...X...		Ambient Temperature:	21.6	°C		
Combined Sensitivity @	250 Hz	and pressure of	99.456 kPa	Ambient Humidity:	53.6	% RH
(Sens. with mic. and preamp.)	0 Volts Polarization voltage (External):	Ambient Pressure:	99.456	kPa		
	-26.69 dB re.1V/Pascal	Calibration Date:	20-Sep-2017			
	46.31 mV/Pascal	Calibration Due:	20-Sep-2018			
	0.69 Ko (- dB re 50 mV/Pascal)	Report Number:	28047 -1			
Sensitivity:	Pass	Control Number:	28047			
Freq. Response:	Pass					
All tests:	Pass					

The above listed instrument meets or exceeds the tested manufacturer's specifications.


The IEC 651:1979 & 1993 Type 1 specification passed.

This Calibration is traceable through NIST test numbers: 683/284413-14

The expanded uncertainty of calibration: 0.079dB at 95% confidence level with a coverage factor of k=2.

The pressure response recorded with electroacoustic method.

Frequency Response



The above listed instrument was checked using calibration procedure documented in West Caldwell

Calibration Laboratories Inc. procedure :

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K

Calibration was performed by West Caldwell Calibration Laboratories Inc. under Operating Procedures

intended to implement the requirements of ISO10012-1, IEC Guide 25, ANSI/NC SL Z540-1, (MIL-STD-45662A) and ISO 9001:2008, ISO 17025

Calibrated on WCCL system type 9700

Measurements performed by:

James Zhu

This document shall not be reproduced, except in full, without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K

West Caldwell Calibration Laboratories Inc.

1575 State Route 96, Victor NY 14564
 Tel. (585) 586-3900 FAX (585) 586-4327

Calibration Data Record

for
 Model No.: 4189-A-021

Brüel & Kjær Microphone Unit
 Company: Aercoustics Engineering LTD

Serial No.: 2622170
 I. D. No.: XXXX

Frequency Response (Reference = 0 dB @ 250Hz)

Frequency [Hz]	Pressure [dB]	Free Field (dB)	Random (dB)
19.95	-0.65	-0.65	-0.65
25.12	-0.38	-0.38	-0.38
31.62	-0.21	-0.21	-0.21
39.81	-0.10	-0.10	-0.10
50.12	-0.04	-0.04	-0.04
63.10	-0.01	-0.01	-0.01
79.43	0.00	0.00	0.00
100.00	0.00	0.00	0.00
125.89	0.00	0.00	0.00
158.49	0.01	0.01	0.01
199.53	0.00	0.00	0.00
251.19	0.00	0.00	0.00
316.23	0.00	0.00	0.00
398.11	-0.01	0.00	-0.01
501.19	-0.01	0.01	-0.01
630.96	-0.02	0.02	-0.02
794.33	-0.04	0.03	-0.04
1000.00	-0.07	0.02	-0.09
1258.93	-0.11	0.04	-0.14
1584.89	-0.20	0.02	-0.25
1995.26	-0.33	-0.01	-0.34
2511.89	-0.51	-0.03	-0.47
3162.28	-0.81	-0.10	-0.77
3981.07	-1.30	-0.23	-1.21
5011.87	-1.80	-0.22	-1.66
6309.57	-2.72	-0.44	-2.41
7943.28	-4.00	-0.62	-3.25
10000.00	-5.41	-0.28	-3.87
12589.25	-6.14	1.05	-3.63
15848.93	-8.16	0.43	-5.57
19952.62	-10.27	-0.22	-7.79

Freq. response: Expanded Uncertainty (dB) with coverage factor K = 2
 20 to 63Hz 0.1dB, 63 to 12.5kHz 0.094dB, 12.5k to 16kHz 0.10dB, 16k to 20kHz 0.5dB.

Instruments used for calibration:	Date of Cal.	Traceability No.	Re-cal. Due Date
Brüel & Kjær 4226 S/N 1445428	3-Nov-2016	683/284413-14	3-Nov-2017
Brüel & Kjær 3560 S/N 2202374	3-Nov-2016	683/284413-14	3-Nov-2017
HP 33120A S/N 36043716	1-Oct-2016	,287708	1-Oct-2017
HP 34401A S/N 36064102	1-Oct-2016	,287708	1-Oct-2017

Cal. Date: 20-Sep-2017

Tested by: James Zhu

Calibrated on WCCL system type 9700

This document shall not be reproduced except in full without the written approval from West Caldwell Cal. Labs. Inc.

Rev. 7.0 Jan. 24, 2014 Doc. # 1038 P4189A021B&K

End of Report
