



Cedar Point II Limited Partnership  
c/o Suncor Energy Products Inc.  
P.O. Box 2844  
150 – 6<sup>th</sup> Avenue S.W.  
Calgary, AB T2P 3E3  
Tel 403-296-8000  
Fax 403-296-3030  
www.suncor.com

July 16, 2015

Ministry of the Environment and Climate Change  
Environmental Assessments and Approvals Branch  
2 St. Clair Avenue West, Floor 12A  
Toronto, ON  
M4V 1L5

VIA COURIER AND EMAIL

**Attention: Mohsen Keyvani, Director**

**Re: Request for Amendment to REA number 6914-9L5JBB Spare Transformer**

---

Suncor Energy Products Inc. (SEPI) received a Renewable Energy Approval number 6914-9L5JBB (REA) on August 22, 2014 for the Cedar Point Wind Power Project (Project). On February 25, 2015 notice was provided to the Director in accordance with the REA that the Project title and assets were assigned to Cedar Point II Limited Partnership (CP II LP). On July 14, 2015, SEPI filed REA amendment application materials to amend the name of the permit holder from SEPI to CP II LP. CP II LP submits this letter and included REA amendment application in **Attachment A** requesting the following amendment to the REA:

- Amending the REA to remove all references to MVA ratings associated with the single transformer proposed for the project.

#### Discussion

CP II LP has sourced a spare transformer which is to be used as a backup in the event of a failure of the original primary transformer proposed for the Project. The spare has been obtained to reduce the down time that would normally occur to procure and manufacture a replacement transformer. As a result throughout the life of the Project, CP II LP is seeking the ability for the REA to permit the use of either the primary or the spare transformer at the coordinate specified for TS1 in Schedule B of the REA.

The spare transformer obtained is manufactured by Prolec GE Engineering Power Division (Prolec GE). The MVA ratings of the transformer are 102/136/170 MVA, and as more power is transformed by the unit, additional cooling equipment is activated which affects sound power level. This specific unit has radiators that cool by natural convection (ONAN), a 1<sup>st</sup> stage forced air cooling (ONAF1) and 2<sup>nd</sup> stage forced air cooling (ONAF2). Prolec GE has confirmed that when the spare transformer is operated at the Project, the 2<sup>nd</sup> stage cooling fans will not be activated regardless of environmental conditions. Please refer to the Prolec GE letter dated July 15, 2015 regarding transformers (serial number G2994-02) use at the Project in **Attachment B**. In addition, Prolec GE has indicated that fans can be removed without affecting the manufacturer's warranty. CP II LP commits to physically disabling the 2<sup>nd</sup> stage cooling fans.

ONAN – oil filled natural cooling

ONAF1 – oil-filled forced-air cooling stage 1

ONAF2 – oil-filled forced-air cooling stage 2

### Sound Power Levels

CP II LP retained HGC Engineering (HGC) to assess the sound power levels of the spare and primary transformer. HGC has identified that the spare transformer, when operated at the Project, will have an overall sound power level of 103.3 dBA which is below the overall sound power level of the primary transformer currently represented in Table B1 and B2 within Schedule B of the REA. The HGC letter memo is provided in **Attachment C**. CP II LP confirms that the sound wall will be constructed as specified in Schedule C of the REA prior to commercial operation of the Project. This confirms that the operation of the spare transformer at the Project will not result in increased negative environmental effects.

### Oil Containment System

An oil containment system has been designed within the substation which can detect the presence of oil and prevent the discharge of water from the containment system. The design volume of the oil containment system is 55,140 L. The volume of oil contained in the spare transformer is 53,400 liters and is absent of poly-chlorinated biphenyl (PCB) content. The oil containment system is appropriately sized to contain the total volume of oil from the transformer in the event of a leak. Please refer to the drawing of the oil containment system, the spare transformer nameplate drawing, and oil test report for the spare transformer in **Attachment D**. No modifications are required to the conditions of section *K – Sewage Works of the Transformer Substation Spill Containment* of the REA as no increased negative environmental effects are anticipated due to the operation of the spare transformer at the Project.

### REA Amendment Requested

The REA 6914-9L5JBB issued on August 22, 2014 contains various references to a “110 MVA” transformer which limits the use of the spare transformer at the site. CP II LP respectfully requests that the REA text be amended to remove any reference to an MVA rating of the transformer.

“110 MVA” would need to be removed in the following locations of the REA:

- Schedule A b) delete “110 mega-volt-ampere (MVA)”;
- Schedule B Table B1 line item TS1 delete “110 MVA” in the source description; and
- Schedule B Table B2 title remove “110 MVA”.

If you require any further details please do not hesitate to contact me.

Yours truly,



Christopher Scott  
Senior Engineer – Renewable Energy  
as Project Technical Information Contact, on behalf of,  
**Cedar Point II Limited Partnership**

Cc: Nick Colella – Ministry of the Environment and Climate Change  
District Manager – Sarnia/Windsor District, Ministry of the Environment and Climate Change

Attachment B

Prolec GE Letter



PROLEC GE S. de R.L. de C.V. ISO 9001 CERTIFIED  
Blvd. Carlos Salinas de Gortari Km. 9.25  
Apodaca, Nuevo León, México  
CP. - 66600

July 15, 2015

Subject: Transformer serial number G2994-02 used at the 100 MW Cedar Point II project.

To: Jennifer Herron  
NextEra Energy, Inc.  
700 Universe Boulevard  
Juno Beach, FL 33408

We have been informed that the GE Prolec transformer serial number G2994-02 might be used at the 100 MW Cedar Point II project, which we understand translates into a maximum transformer load of 111MVA.

Since this transformer is designed for 170 MVA, it has a cooling capacity far beyond what will be used at this project. GE Prolec confirms that when operated at 111 MVA at the Cedar Point II project, the second stage cooling fans will not be activated regardless of environmental conditions.

However, we understand that because of the differences in layout of the radiators and fans on G2994-02 GE Prolec transformer from the originally planned unit, the second stage cooling equipment will be removed to allow a proper fit into the Cedar Point II substation, and the transformer's design will provide adequate cooling without this equipment installed. In addition, the transformer's warranty will be unaffected by removal of the second stage cooling equipment.

Sincerely yours.

A handwritten signature in black ink, appearing to read "M. Resendiz Boone".

Manuel Resendiz Boone  
Commercial Manager - Power Transformers  
Prolec GE Industrias S. de R.L. de C.V.  
Tel + 52 (81) 8030-2292  
E-Mail: Manuel.Resendiz@ge.com

Attachment C

HGC Engineering Memo – Spare Transformer

July 15, 2015

[cscott@suncor.com](mailto:cscott@suncor.com)

**Chris Scott**  
**Suncor Energy Products Inc.**  
150 6<sup>th</sup> Avenue SW  
Calgary, Alberta  
T2P 3E3

**Re: Transformer Sound Levels**  
**Suncor Cedar Point Wind Energy Project, Lambton County, Ontario**

---

Dear Mr. Scott,

As requested, HGC Engineering has reviewed details regarding the spare transformer proposed for the Cedar Point Wind Energy Project.

The original transformer proposed for the site is a General Electric 66/88/110 MVA transformer with a maximum sound power level of 103.6 dBA including the +5 dBA tonality penalty. Details of this transformer are included under the Noise Assessment Report, dated May 20, 2014, prepared by HGC Engineering.

The proposed spare transformer is a General Electric 102/136/170 MVA transformer which will have a maximum NEMA sound level of 74 dB (ONAF 1) measured in accordance with IEEE Standard C57.12.90, "IEEE Standard Test Code for Liquid Immersed Distribution, Power and Regulating Transformers". Using the drawings for the transformer, an enclosing surface area estimate of 268 m<sup>2</sup> was determined. The NEMA sound rating and the measurement surface area was used to compute the overall maximum sound power level of 103.3 dBA including the +5 dBA tonality penalty, which is less than the original proposed transformer. Calculation details are attached.

We trust this meets your requirements.

Yours truly,  
**Howe Gastmeier Chapnik Limited**



Ian Bonsma, PEng  
Senior Engineer, Associate

**Transformer - Cedar Point, Prolec 102 / 136 / 170 MVA**

NEMA  
Surface

$$L_w = L_p + 10 \cdot \log S$$

1 Ft ONAN / 6 Ft ONAF LwA  
**98.3**

Lp      S  
**74**      **268** m<sup>2</sup>

Total Perimeter: **36.9**  
Height: **4.6**  
Top Surface: **99.7**

	31.5	63	125	250	500	1000	2000	4000	8000	A
Adjustment Value	-3	3	5	0	0	-6	-11	-16	-23	
Sound Power Level	95.3	101.3	103.3	98.3	98.3	92.3	87.3	82.3	75.3	<b>98.3</b>
	Tonal Penalty: 5									
	Penalized A-Weighted Sum: 103.3									




ACOUSTICS



NOISE



VIBRATION



**NOTES:**

- ITEMS REMOVED FOR SHIPMENT ARE MARKED WITH (-).
- NUMBERING IS ACCORDING WITH G.E. PROLEC STD. LIST.
- THE NUMBER IN COLUMN "GUIDE" CORRESPONDS TO THE "IN-FIELD ASSEMBLY GUIDE".

**TOLERANCES**

Centerline distance of not inclined bushings	+0.25 (-0.25)
Centerline distance of inclined bushings	+0.50 (-0.25)
Bushings height (distance to floor)	+0.25 (-0.25)
Outlet of surge cabinet distance	+0.25 (-0.25)
Hv & Lv bushings center line	+0.25 (-0.25)
Bushings & surge arrester center line	+0.25 (-0.25)
Surge arrester height (distance to floor)	+0.50 (-0.25)
Center tank distance to short side	+0.50 (-0.25)
Center tank distance to large side	+0.50 (-0.25)
Conservator height	+0.25 (-0.25)
Anchoring center line	+0.25 (-0.25)
Bracing base center line	+0.25 (-0.25)
Pattern distance	+0.08 (-0.08)
Outline	0-118.00 (-0.2000)
Dimensions	118.00-127.00 (-0.2000-0.5000)
	127.00 & Above (-0.2000 & Above)
	22.00 (-0.50)

**OPERATION CENTER OF GRAVITY**  
**SHIPPING CENTER OF GRAVITY**



GENERAL ELECTRIC CANADA  
 PROLEC GE G2994-02  
 Serial No: 512-03799  
 P.O. No: 512-03799  
 GE Req No: TD704723  
 M & S No: 49M221102  
 Substation: JERICHO

**PROLEC**  
 APPROVAL DRAWING  
 OCT/18/2013  
 DEAR CUSTOMER:  
 WE WANT TO SERVE YOU BETTER.  
 PLEASE REVIEW THIS DRAWING  
 AND SEND BACK WITH YOUR  
 COMMENTS TO PROLEC-GE IN THE  
 TIMEFRAME OF 10 DAYS AFTER  
 THE DATE MARKED IN THIS STAMP.

STEP UP TRANSFORMER  
 ONAN/ONAF/ONAF  
 102/136/170 MVA  
 60 HZ. THREE PHASE, 65°C, 1000 MASL  
 121/69.86 KV Δ - 34.5 KV Δ





**APPROXIMATE WEIGHTS ( KGS )**

CORE AND COILS	94780
TANK AND FITTINGS	40330
MAIN TANK INSULATING LIQUID (45730 LITS)	41160
COOLING EQUIPMENT INSULATING LIQUID (4015 LITS)	3615
CONSERVATOR TANK INSULATING LIQUID ( 2355 LITS )	2120
LTC TANK INSULATING LIQUID ( 1300 LITS )	1170
TOTAL WEIGHT	183175
UNTANKING WEIGHT ( HEAVIEST PIECE )	94780
SHIPPING WEIGHT (WITHOUT INSULATING LIQUID)	116240



\* THE HATCHED AREA REPRESENT THE BOTTOM OF THE TRANSFORMER, THIS AREA IS NOT IN CONTACT WITH FOUNDATION OR PAD

CODE	QTY.	ITEM	DESCRIPTION	CAT./MOD.
1	1	10	LIQUID TEMPERATURE INDICATOR (260-1)	QUALITROL, 104-685-03
5.4	1	24	THERMO-Well FOR LIQUID TEMPERATURE INDICATOR	QUALITROL, 208-60F
5.6	1	5	PRESSURE RELIEF DEVICE WITH SEMAPHORE (639R-1.2)	QUALITROL, 900-003-02
	1	15	RAPID PRESSURE RELAY VALVE (2.00 ø) BALL-TYPE	
	1	7	THERMO-Well FOR RESISTANCE TEMPERATURE DEVICE FOR ETM (TOP)	
	1	10	ELECTRONIC TEMPERATURE MONITOR (INSIDE CONTROL CABINET)	APT, ECLIPSE-000H
	1	100	RESISTANCE TEMPERATURE DEVICE FOR ETM (TOP OIL) RTD-1	
	1	106	RESISTANCE TEMPERATURE DEVICE FOR ETM (AMBIENT) RTD-2	
5.15	1	11	PRESSURE-VACUUM GAUGE FOR SHIPPING	QUALITROL, 050-35E
5.15	1	14	H.V. BUSHING EXTERNAL CONNECTOR	DELTA, PM59C12-1-4N4-E
5.15	1	140	L.V. BUSHING EXTERNAL CONNECTOR	DELTA, PM60C12-1-422-M1-E
3.2	1	15	H.V. BUSHING	BURNDY, FD67C12W
3.2	1	16	L.V. BUSHING	FOCRE, POC650G1216CMS
3.2	1	19	NEUTRAL BUSHING HD	ABB 034Z3000AS
4.2	1	25	H.V. SURGE-ARRESTERS	SIEMENS, 3E04 108-2PK31-4NH5
4.1	1	26	BUSHING TO SURGE-ARRESTER FLEXIBLE CONNECTOR	
4.2	1	27	L.V. SURGE-ARRESTER	SIEMENS 3E04 045-2PD31-4NH5
4.1	1	28	L.V. SURGE-ARRESTER SUPPORT	
	1	37	H.V. SURGE-ARRESTERS GROUND CABLE CONNECTOR	
	1	37	H.V. SURGE-ARRESTERS GROUND CABLE CONNECTOR	
	1	38	H.V. SURGE-ARRESTERS COPPER GROUND CABLE	
	1	38	L.V. SURGE-ARRESTERS COPPER GROUND CABLE	
5	1	40	GROUND PAD	
	1	41	NEUTRAL HD GROUND PAD	
	1	42	CORE GROUND BUSHING TERMINAL BOX (MAIN UNIT)	
	1	43	FRAME GROUND BUSHING BOX	
	1	45	CORE GROUND BUSHING BOX (SERIES UNIT)	
	1	46	NAMEPLATE	
	1	46	IDENTIFICATION NAMEPLATE	
	1	47	CONTROL CABINET	
	1	51	REINFORCED BASE WELDED TO TANK	
	1	51	TRANSFORMER ANCHOR PADS	
	1	53	TANK BRACES	
	1	55	COVER BRACES	
	1	56	LIFTING PADS AND PULLING EYES	
	1	57	MAIN COVER	
	1	58	INSPECTION MANHOLE (COVER)	
	1	60	INSPECTION RECTANGULAR MANHOLE (COVER)	
	1	60	CT TERMINAL BOX	
	1	66	LIFTING EYE COVER ONLY	
	1	67	LIFTING HOOK FOR LIFTING COMPLETE UNIT	
	1	68	SHIPPING LUGS FOR SECURING THE UNIT LONGITUDINALLY (SHORT LUGS)	
	1	68	SHIPPING LUGS FOR SECURING THE UNIT LONGITUDINALLY (LONG LUGS)	
	1	72c	TOP FILTER PRESS VALVE (50.8 ø) GLOBE-TYPE	
	1	73	MAIN TANK DRAIN VALVE (50.8ø) GLOBE-TYPE WITH SAMPLING DEVICE (9.65 AND PLUG	
	1	74	IMPACT RECORDER FOR SHIPPING	
	1	74	ELECTRONIC IMPACT RECORDER FOR SHIPPING	
	1	75	COOLING RADIATORS	
	1	75b	RADIATOR VENT AND DRAIN PLUG (25.4 ø)	
	1	75c	RADIATOR VALVE BUTTERFLY-TYPE (101.6 ø)	
	1	75d	COOLING FAN	KRENZ, F260-A9712
	1	75e	TOP/BOTTOM RADIATOR SUPPORTS	
	1	76	CONSERVATOR TANK WITH INTERNAL BLADDER	QUALITROL, 042-144-07
2.3	1	76a	CONSERVATOR TANK SUPPORT	
2.1	1	76b	MAGNETIC LIQUID LEVEL GAUGE (710-1)	
2.2	1	76c	HANDHOLE TO INSTALL BLADDER	
5.8	1	76d	SILICA-GEL BREATHER WITH PIPE	MESSKO, DB200-RM-T
5.8	1	76e	SILICA-GEL SHUT OFF VALVE (12.7 ø) BALL-TYPE	
5.8	1	76f	CONSERVATOR PRESSURE EQUALIZATION VALVE (25.4 ø) GLOBE-TYPE	
5.8	1	76g	CONSERVATOR FILL VALVE (50.8 ø) GLOBE-TYPE	
5.8	1	76i	CONSERVATOR DRAIN VALVE (50.8 ø) GLOBE-TYPE	
5.8	1	76j	CONSERVATOR TANK NIPPLE FOR VENT WITH CAP	
2.2	1	76k	CONSERVATOR TANK TO MAIN TANK VALVE (76.2 ø) BALL-TYPE	QUALITROL, 038-002-02
5.13	1	76l	GAS SAMPLING DEVICE	
2.4	1	76m	GAS ACCUMULATION DEVICE (636-1)	
5.8	1	76n	EXPANSION JOINT FOR PIPING	MR, RMV-II-1500-72.5
	1	77	ON-LOAD TAP-CHANGER	
	1	77a	LTC MAGNETIC LIQUID LEVEL GAUGE (710-2)	
	1	77b	LTC PRESSURE RELIEF DEVICE (636R)	
	1	77c	LTC DRAIN VALVE (25.4 ø) GATE-TYPE WITH SAMPLING DEVICE (9.65 ø) AND PLUG	
	1	77d	LTC SILICA-GEL BREATHER WITH PIPE	
	1	77e	LTC MOTOR DRIVE CABINET	
	1	77f	LTC PRESSURE-VACUUM GAUGE FOR SHIPPING	
	1	77g	TELEHER POLE MOUNTING PLATE	
	1	77h	VALVES FOR INSTALLATION OF A KELMAN MINITRANS DGA MONITOR (BALL TYPE)	



**PROLEC** THIS DRAWING CONTAINS PROPRIETARY INFORMATION WHICH CAN NOT BE REPRODUCED WITHOUT PERMISSION OF PROLEC GE.

PROLEC GE ENGINEERING POWER DIVISION  
<http://www.prolecge.com>

TITLE: TRANSFORMER'S OUTLINE

DFTM: 10.18.2013  
 CHKD: AGS

R.D.L.C.  
 AGS

PROJECTION

SCALE: 1:45

DIMENSIONS: MM

REVISION: INDICATED

DRAWING NO.: G299402D801

sheet: 1 of 1

Date: Mar/07/2015

# TRANSFORMER TEST REPORT


102.000 / 136.000 / 170.000 MVA

121.00Y-34.50 kV

ONAN / ONAF / ONAF2

Serial No: **G2994-02**

Purchaser: **GENERAL ELECTRIC CANADA**

  
\_\_\_\_\_  
Test Engineer  
\_\_\_\_\_  
Moisés Rodríguez C.  
Test Leader  
\_\_\_\_\_  
Design Engineer

This report can not be reproduced neither partially or totally without previous consent from the Test Department

**Purchaser :** GENERAL ELECTRIC CANADA  
**Rating :** 102.000/136.000/170.000 MVA

**Serial No:**G2994-02  
**Date :**03/07/2015

**AUDIBLE SOUND LEVEL MEASUREMENTS (dB)**

**RATING :** ONAF1

H.V. TAP POSITION : NOM  
 L. V. TAP POSITION : NOM

**TEST VOLTAGE :** 34500 V

1. Before test meas.	
Side	Ambient
A	65.2
B	66.0
C	65.7
D	66.4

3.- After test meas.	
Side	Ambient
A	65.1
B	65.4
C	64.2
D	64.6

4.- Average Ambient
65.0

6.- Average Corrected
70.0


Pos.	2.- Ambient + Transformer meas.		5.- Corrected Transformer meas.	
	1/3 Height	2/3 Height	1/3 Height	2/3 Height
1	71.2	71.6	69.9	70.6
2	70.6	70.9	69.3	69.6
3	70.4	71.4	68.8	70.1
4	71.2	71.7	69.9	70.7
5	71.6	70.9	70.6	69.6
6	70.3	71.6	68.7	70.6
7	70.1	71.4	68.5	70.1
8	69.9	70.9	68.3	69.6
9	70.6	71.2	69.3	69.9
10	71.2	70.6	69.9	69.3
11	71.9	70.8	70.9	69.5
12	70.9	71.3	69.6	70.0
13	71.6	71.2	70.6	69.9
14	71.4	70.7	70.1	69.4
15	71.3	71.7	70.0	70.7
16	71.2	72.1	69.9	71.1
17	70.3	72.3	68.7	71.3
18	69.9	70.6	68.3	69.3
19	70.6	71.4	69.3	70.1
20	71.2	71.1	69.9	69.8
21	69.9	70.7	68.3	69.4

Guaranteed Level 74 dB

Average transformer sound pressure level at ANSI surface (Lp) 70.0 db(A)  
 Height of the Transformer tank (H) 4.0 m  
 Length of the prescribed contour (Pm) 39.5 m  
 Measurement Surface Area (S) 198 m<sup>2</sup>  
 Sound Power Level (Lw) 93.0 db(A)

**Results : Accepted**

COMMENTS :

  
 Test Engineer

  
 Design Engineer

This report can not be reproduced neither partially or totally without previous consent from the Test Department

**Purchaser :** GENERAL ELECTRIC CANADA  
**Rating :** 102.000/136.000/170.000 MVA

**Serial No:**G2994-02  
**Date :**03/07/2015

**AUDIBLE SOUND LEVEL MEASUREMENTS (dB)**

**RATING :** ONAF1

H.V. TAP POSITION : NOM  
 L. V. TAP POSITION : NOM

TEST VOLTAGE : 34500 V

1. Before test meas.	
Side	Ambient
A	65.2
B	66.0
C	65.7
D	66.4

3.- After test meas.	
Side	Ambient
A	65.1
B	65.4
C	64.2
D	64.6

4.- Average Ambient
65.0

6.- Average Corrected
70.0

Pos.	2.- Ambient + Transformer meas.		5.- Corrected Transformer meas.	
	1/3 Height	2/3 Height	1/3 Height	2/3 Height
22	71.0	71.8	69.7	70.8
23	70.3	71.3	68.7	70.0
24	70.2	70.9	68.6	69.6
25	71.4	70.6	70.1	69.3
26	70.6	71.6	69.3	70.6
27	71.4	70.9	70.1	69.6
28	70.6	70.8	69.3	69.5
29	71.4	70.6	70.1	69.3
30	71.2	71.6	69.9	70.6
31	70.4	70.9	68.8	69.6
32	71.4	71.4	70.1	70.1
33	71.0	71.7	69.7	70.7
34	70.6	71.2	69.3	69.9
35	71.3	70.6	70.0	69.3
36	70.9	71.3	69.6	70.0
37	70.6	71.7	69.3	70.7
38	71.2	70.9	69.9	69.6
39	71.4	71.6	70.1	70.6
40	71.6	71.9	70.6	70.9


Guaranteed Level 74 dB

Average transformer sound pressure level at ANSI surface (Lp) 70.0 db(A)  
 Height of the Transformer tank (H) 4.0 m  
 Length of the prescribed contour (Pm) 39.5 m  
 Measurement Surface Area (S) 198 m  
 Sound Power Level (Lw) 93.0 db(A)

**Results : Accepted**

COMMENTS :


  
 Test Engineer

  
 Design Engineer


This report can not be reproduced neither partially or totally without previous consent from the Test Department

Attachment D


Oil Containment System Design Drawing, Prolec GE Nameplate Drawings and Oil Testing Results




**F1 - TRANSFORMER CONTAINMENT PIT - PLAN**  
SCALE 1:100 (DD20-DTL-0161)




**DETAIL 1**  
1:30




**SECTION B**  
1:30




**DETAIL 2**  
1:30




**SECTION C**  
1:30




**DETAIL 3**  
1:30



**SECTION D**  
1:30




**DETAIL 4**  
1:30




**SECTION E**  
1:30

- NOTES:**
- ALL DIMENSIONS ARE IN MILLIMETERS AND ALL ELEVATIONS ARE IN METERS.
  - FOR FOUNDATION PLAN SEE AMEC DWG. DD20-LYD-0161.001.
  - FOR GENERAL NOTES SEE AMEC DWG. DD20-DTL-0160.001
  - OIL CONTAINMENT AREA FILLED WITH "VOID STONE" COMPLYING WITH THE FOLLOWING:
    - VOID STONE CONSISTS OF WASHED ROUNDED GRAVEL UNIFORMLY GRADED TO 25mm (100% PASSING 38mm SIEVE, 0% PASSING 19mm SIEVE). MATERIAL CONSISTS OF CLEAN, HARD, DURABLE PARTICLES.
    - A MINIMUM OF 35% VOLUME OF VOIDS IS REQUIRED AND CONTRACTOR SUBMITTED CERTIFICATION OF THIS.
    - VOID STONE MEETS REQUIREMENTS OF ONTARIO PROVINCIAL STANDARD CERTIFICATION 1010 AND SHALL BE DURABLE AND FREE OF SHALE OR OTHER NON-DURABLE MATERIAL. ALTERNATIVE GRADATION CAN BE USED SUBJECT TO APPROVAL.
  - REFER TO CIVIL SITE GRADING PLAN DWG. 173709-0200-DD10-LYD-0128.002 FOR SUMP DETAILS.




**EARTHWORK TYPICAL SECTION (U.N.O)**  
1:100


**SECTION A**  
1:50




**SECTION F**  
1:50





**F2 - CIRCUIT BREAKER FOUNDATION - PLAN**  
1:50 (DD20-LYD-0161)



**DETAIL 5**  
1:10



**DETAIL 6**  
1:10



**SECTION G**  
1:30

REV	DDMMYY	REVISION / ISSUE DESCRIPTION	DRN	CHK	APP	APP	APP	APP	APP	REV	DDMMYY	REVISION / ISSUE DESCRIPTION	DRN	CHK	APP	APP	APP	APP	APP	
1	31MAR15	RE-ISSUED FOR CONSTRUCTION																		
0	05MAR15	ISSUED FOR CONSTRUCTION																		
E	28NOV14	RE-ISSUED FOR BID																		
D	20AUG14	ISSUED FOR BID																		
C	20AUG14	ISSUED FOR REVIEW																		
B	18AUG14	ISSUED FOR SQUAD CHECK																		
A	10FEB14	ISSUED FOR INFORMATION																		

UNLESS OTHERWISE ADVISED IN A WRITTEN CONTRACT BETWEEN AMEC AND ITS CLIENT, THIS AMEC DOCUMENT CONTAINS INFORMATION THAT IS CONFIDENTIAL AND NOT TO BE COPIED OR DISCLOSED AND IS TO BE USED ONLY BY THE CLIENT IN THE CONTEXT AND FOR THE PURPOSES FOR WHICH IT WAS DELIVERED. ANY OTHER USE OR RELIANCE ON THIS DOCUMENT BY ANY THIRD PARTY IS AT THAT PARTY'S SOLE RISK AND RESPONSIBILITY.

STAMP/SEAL

PROJECT NO.	ACTIVITY NO.	BY	DDMMYY	SUBJECT
173709		DES	28JAN14	CEDAR POINT II SUBSTATION FOUNDATIONS F1 & F2 PLANS, SECTIONS & DETAILS
SCALE	PACKAGE CODE	DRN	28JAN14	
AS NOTED		CHK	28JAN14	
		APP	28JAN14	

**SUNCOR ENERGY**

**amec**

AREA	0200	SUNCOR ENERGY CEDAR POINT II WIND POWER PROJECT
CLIENT DWG. NO.		
DRAWING NO.	173709-0200-DD20-DTL-0162.001	REV. 1

GENERAL ELECTRIC CANADA	
PROLEC GE	G2994-02
Serial No:	512-03799
P.O. No:	1D704723
GE Req No:	49M221102
M & S No:	JERICHO
Substation:	

STEP UP TRANSFORMER  
ONAN/ONAF/ONAF  
102/136/170 MVA  
60 HZ, THREE PHASE, 65°C, 1000 MASL  
121/69.86 KV - 34.5 KV

**PROLEC**  
APPROVAL DRAWING  
OCT/18/2013  
OFFER CUSTOMER, BETTER  
WE WANT TO SERVE YOU, BETTER  
PLEASE REVIEW THIS DRAWING  
AND SEND BACK WITH YOUR  
COMMENTS TO PROLEC. AFTER  
THE DATE MARKED IN THIS STAMP.



http://www.prolecge.com

## LOAD-TAP-CHANGING TRANSFORMER

SERIAL No **G2994** \_\_\_, THREE-PHASE, 60 Hz, ALTITUDE 1000 m



VOLTAGE RATING <b>121 000 GrdY / 69860 - 34 500</b>			
COOLING CLASS	MVA RATING	AMBIENT TEMPERATURE	SERVICE CONDITIONS
ONAN	102.0	30°C	CONTINUOUS @ 65°C RISE
ONAF	136.0		
	170.0	0°C	CONTINUOUS

APPROXIMATE WEIGHTS ( KGS )	
CORE AND COILS	94780
TANK AND FITTINGS	40330
MAIN TANK INSULATING LIQUID (45730 LITS)	41160
COOLING EQUIPMENT INSULATING LIQUID (4015 LITS)	3615
CONSERVATOR TANK INSULATING LIQUID ( 2355 LITS)	2120
LTC TANK INSULATING LIQUID ( 1300 LITS )	1170
TOTAL WEIGHT	183175
UNTANKING WEIGHT ( HEAVIEST PIECE )	94780
SHIPPING WEIGHT (WITHOUT INSULATING LIQUID)	116240

IMPEDANCE @ 85 °C		
%Z	MVA BASE	kV BASE
	102	121 - 34.5


LIGHTNING IMPULSE LEVEL (kV)			
	H1,H2,H3	X1,X2,X3	HO
BUSHING	650	200	200
WINDING	550	200	200

LOW VOLTAGE WINDING	
VOLTS	AMPERES
X1, X2, X3	170 000 KVA
34 500	2845



CUSTOMER SERIAL No.

HIGH VOLTAGE WINDING		LOAD TAP CHANGER	
VOLTS	AMPERES	DIAL POSITION	CONNECTS
H1, H2, H3	170 000 KVA		P4 TO P1 TO
133 100	737	16L	4 4
132 350	742	15L	5 4
131 600	746	14L	5 5
130 825	750	13L	6 5
130 075	755	12L	6 6
129 325	759	11L	7 6
128 575	763	10L	7 7
127 800	768	9L	8 7
127 050	773	8L	8 8
126 300	777	7L	9 8
125 550	782	6L	9 9
124 775	787	5L	10 9
124 025	791	4L	10 10
123 275	796	3L	11 10
122 525	801	2L	11 11
121 750	806	1L	M 11
121 000	811	N	M M
120 250	816	1R	4 4
119 500	821	2R	4 4
118 725	827	3R	5 4
117 975	832	4R	5 5
117 225	837	5R	5 5
116 475	843	6R	6 5
115 700	848	7R	6 6
114 950	854	8R	7 6
114 200	860	9R	7 7
113 450	865	10R	8 7
112 675	871	11R	8 8
111 925	877	12R	9 8
111 175	883	13R	9 9
110 425	889	14R	10 9
109 650	895	15R	10 10
108 900	901	16R	11 10



### CAUTION !

- BEFORE INSTALLING OR OPERATING READ INSTRUCTIONS **G2994**
- DO NOT OPERATE TRANSFORMER WHEN THE READING OF LIQUID LEVEL GAUGE IS BELOW THE LOW POINT OF THE SCALE.

### NOTES

- MAXIMUM OPERATING PRESSURES OF LIQUID PRESERVATION SYSTEM: 0 KPa ( ATMOSPHERIC PRESSURE ).
- TANK DESIGNED FOR 103.42 KPa VACUUM FILLING
- ALL WINDINGS COPPER.
- FILLED WITH INSULATING LIQUID WHICH CONTAIN NO DETECTABLE LEVEL OF PCB AT THE TIME OF MANUFACTURE.
- LIFTING, MOVING AND JACKING FACILITIES MUST NOT BE USED IN AMBIENT TEMPERATURES LOWER THAN -40°C.
- BUILT TO CAN/CSA C88-M90 STANDARD

CSA-C88-M90

SUITABLE FOR STEP UP OPERATION

MANUFACTURE DATE: \_\_\_ / 20 \_\_\_



TRANSFORMER DESIGNED FOR NOMINAL IMPEDANCE VOLTS OF 8.0 % AT 102000 KVA THE ACTUAL MEASURED IMPEDANCE VALUE WILL BE SHOWN ON THE NAMEPLATE.

MATERIAL: STAINLESS STEEL. PS DIMENSIONS: 610 mm. x 305 mm.

REV	DESCRIPTION
DESIGN GROUP	2
PROLEC GE ENGINEERING POWER DIVISION	
NAMEPLATE	
TITLE: http://www.prolecge.com	
THIS DRAWING CONTAINS PROPRIETARY INFORMATION WHICH CAN NOT BE REPRODUCED WITHOUT PERMISSION OF PROLEC GE.	
DFTM: JEGCL	PROJECTION
CHKD: AGS	SCALE: NONE
02/12/2013	DIMENSIONS IN: NONE
02/12/2013	REVISION: INDICATED
G299402D802	DRAWING NO.:
SHEET: 1 of 1	

**Purchaser:** GENERAL ELECTRIC CANADA  
**Rating:** 102.000/136.000/170.000 MVA

**Serial No:** G2994-02  
**Date:** 03/06/2015

**INSULATING FLUID ANALYSIS  
PCB's CONTENT IN OIL ANALYSIS**

**ANALYSIS TYPE: DETERMINATION OF PCB's CONTENT (AS AROCLOR 1260)**

**Temperature:** 25 °C


**RESULT (PPM)**


QUANTITY	METHOD
<u>NO DETECTED:</u>	<u>ASTMD-4059</u>

**Diagnostic:** OIL ACCEPTED:

Equipment: HP5890 Serial 02

Form 10.15-A REV. 2

  
Approval

  
Material Inspector

This report can not be reproduced either partially or totally without previous consent from the test department